



Experience is the solution

314 North Pearl Street ♦ Albany, New York 12207
(800) 848-4983 ♦ (518) 434-4546 ♦ Fax (518) 434-0891

February 12, 2020

Clifford Nooney
Guilderland CSD
PO Box 381

Guilderland Center, NY 12085

TEL: (518) 456-6200

Work Order No: 200131011

RE: 2020 Lead Sampling and Analysis
Guilderland High School

Dear Clifford Nooney:

Adirondack Environmental Services, Inc received 162 samples on 1/31/2020 for the analyses presented in the following report.

Please see case narrative for specifics on analysis.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,

Monica Higdon
Laboratory Manager

ELAP#: 10709

Adirondack Environmental Services, Inc**CASE NARRATIVE****CLIENT:** Guilderland CSD**Date:** 12-Feb-20**Project:** 2020 Lead Sampling and Analysis**Lab Order:** 200131011

The sampling was performed in accordance with the AES field sampling procedures and/or the client specified sampling procedures. Sample containers were supplied by Adirondack Environmental Services.

Definitions - RL: Reporting Limit DF: Dilution factor

Qualifiers:	ND : Not Detected at reporting limit	C: CCV below acceptable Limits
	J: Analyte detected below quantitation limit	C+: CCV above acceptable Limits
	B: Analyte detected in Blank	S: LCS Spike recovery is below acceptable limits
	X : Exceeds maximum contamination limit	S+: LCS Spike recovery is above acceptable limits
	H: Hold time exceeded	Z: Duplication outside acceptable limits
	N: Matrix Spike below acceptable limits	T : Tentatively Identified Compound-Estimated
	N+: Matrix Spike is above acceptable limits	E :Above quantitation range-Estimated

Note : All Results are reported as wet weight unless noted**The results relate only to the items tested. Information supplied by the client is assumed to be correct.**

Adirondack Environmental Services, Inc

Date: 12-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Guilderland High School

LabWork Order: 200131011
PO#:

Lab SampleID: 200131011-001 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-E01 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	1.6	1.0		µg/L	1	2/5/2020 4:13:26 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200131011-002 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-E02 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	4.8	1.0		µg/L	1	2/5/2020 4:24:40 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200131011-003 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-E03 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	1.5	1.0		µg/L	1	2/5/2020 4:28:26 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200131011-004 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-E05 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	7.9	1.0		µg/L	1	2/5/2020 4:32:11 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200131011-005 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-E06 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	2.7	1.0		µg/L	1	2/5/2020 4:43:25 PM
------	-----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 12-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Guilderland High School

LabWork Order: 200131011
PO#:

Lab SampleID: 200131011-006 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-E07 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	7.2	1.0		µg/L	1	2/5/2020 4:47:11 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200131011-007 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-E08 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	6.0	1.0		µg/L	1	2/5/2020 4:50:58 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200131011-008 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-E09 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	6.0	1.0		µg/L	1	2/5/2020 4:54:40 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200131011-009 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-E10 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	8.4	1.0		µg/L	1	2/5/2020 4:58:23 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200131011-010 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-E11 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	ND	1.0		µg/L	1	2/5/2020 5:02:06 PM
------	----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 12-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Guilderland High School

LabWork Order: 200131011
PO#:

Lab SampleID: 200131011-011 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-E12 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	ND	1.0		µg/L	1	2/5/2020 5:05:49 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200131011-012 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-E13 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	5.7	1.0		µg/L	1	2/5/2020 5:17:01 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200131011-013 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-E14 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	4.1	1.0		µg/L	1	2/5/2020 5:28:13 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200131011-014 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-E15 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	3.1	1.0		µg/L	1	2/5/2020 5:31:57 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200131011-015 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-E16 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	3.0	1.0		µg/L	1	2/5/2020 5:35:42 PM
------	-----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 12-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Guilderland High School

LabWork Order: 200131011
PO#:

Lab SampleID: 200131011-016 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-E17 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	ND	1.0		µg/L	1	2/5/2020 5:39:28 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200131011-017 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-E18 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	5.3	1.0		µg/L	1	2/5/2020 5:43:14 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200131011-018 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-E29 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	2.3	1.0		µg/L	1	2/5/2020 5:46:57 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200131011-019 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-E41 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	ND	1.0		µg/L	1	2/5/2020 5:50:39 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200131011-020 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-E42 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	4.3	1.0		µg/L	1	2/5/2020 5:54:22 PM
------	-----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 12-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Guilderland High School

LabWork Order: 200131011
PO#:

Lab SampleID: 200131011-021 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-E43 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	2.4	1.0		µg/L	1	2/5/2020 6:13:00 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200131011-022 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-E44 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	14.8	1.0		µg/L	1	2/5/2020 6:24:13 PM
------	------	-----	--	------	---	---------------------

Lab SampleID: 200131011-023 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-E96 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	5.6	1.0		µg/L	1	2/5/2020 6:27:58 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200131011-024 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-E97 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	7.8	1.0		µg/L	1	2/5/2020 6:31:43 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200131011-025 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-E98 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	4.8	1.0		µg/L	1	2/5/2020 6:35:29 PM
------	-----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 12-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Guilderland High School

LabWork Order: 200131011
PO#:

Lab SampleID: 200131011-026 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-E99 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	3.2	1.0		µg/L	1	2/5/2020 6:39:12 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200131011-027 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-E100 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	4.9	1.0		µg/L	1	2/5/2020 6:42:55 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200131011-028 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-E168 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	2.8	1.0		µg/L	1	2/5/2020 6:46:38 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200131011-029 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-E169 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	14.5	1.0		µg/L	1	2/5/2020 6:57:48 PM
------	------	-----	--	------	---	---------------------

Lab SampleID: 200131011-030 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-E170 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	8.7	1.0		µg/L	1	2/5/2020 7:01:32 PM
------	-----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 12-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Guilderland High School

LabWork Order: 200131011
PO#:

Lab SampleID: 200131011-031 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-E174 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	2.6	1.0		µg/L	1	2/5/2020 7:05:15 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200131011-032 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-E176 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	ND	1.0		µg/L	1	2/5/2020 7:16:28 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200131011-033 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-E180 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	5.4	1.0		µg/L	1	2/5/2020 7:20:13 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200131011-034 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-E185 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	ND	1.0		µg/L	1	2/5/2020 7:23:58 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200131011-035 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-E41B **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	7.3	1.0		µg/L	1	2/5/2020 7:27:44 PM
------	-----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 12-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Guilderland High School

LabWork Order: 200131011
PO#:

Lab SampleID: 200131011-036 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-E42A **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	1.3	1.0		µg/L	1	2/5/2020 7:31:28 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200131011-037 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-E42C **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	4.0	1.0		µg/L	1	2/5/2020 7:35:11 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200131011-038 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W01 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	1.1	1.0		µg/L	1	2/5/2020 7:46:22 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200131011-039 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W02 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	2.0	1.0		µg/L	1	2/5/2020 7:50:05 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200131011-040 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W03 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	1.5	1.0		µg/L	1	2/5/2020 7:53:49 PM
------	-----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 12-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Guilderland High School

LabWork Order: 200131011
PO#:

Lab SampleID: 200131011-041 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W04 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	1.3	1.0		µg/L	1	2/5/2020 8:05:01 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200131011-042 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W05 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	1.2	1.0		µg/L	1	2/5/2020 8:16:16 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200131011-043 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W06 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	1.7	1.0		µg/L	1	2/5/2020 8:20:02 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200131011-044 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W07 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	2.2	1.0		µg/L	1	2/5/2020 8:31:13 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200131011-045 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W08 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	3.1	1.0		µg/L	1	2/5/2020 8:34:57 PM
------	-----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 12-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Guilderland High School

LabWork Order: 200131011
PO#:

Lab SampleID: 200131011-046 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W09 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	1.7	1.0		µg/L	1	2/5/2020 8:38:41 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200131011-047 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W10 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	2.0	1.0		µg/L	1	2/5/2020 8:42:25 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200131011-048 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W11 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	1.4	1.0		µg/L	1	2/5/2020 8:46:09 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200131011-049 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W12 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	1.3	1.0		µg/L	1	2/5/2020 8:49:53 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200131011-050 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W13 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	1.5	1.0		µg/L	1	2/5/2020 8:53:37 PM
------	-----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 12-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Guilderland High School

LabWork Order: 200131011
PO#:

Lab SampleID: 200131011-051 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W14 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	2.0	1.0		µg/L	1	2/5/2020 8:57:22 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200131011-052 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W15 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	3.1	1.0		µg/L	1	2/5/2020 9:16:05 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200131011-053 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W16 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	1.8	1.0		µg/L	1	2/5/2020 9:19:50 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200131011-054 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W17 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	1.0	1.0		µg/L	1	2/5/2020 9:23:34 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200131011-055 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W18 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	1.4	1.0		µg/L	1	2/5/2020 9:27:19 PM
------	-----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 12-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Guilderland High School

LabWork Order: 200131011
PO#:

Lab SampleID: 200131011-056 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W19 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	3.3	1.0		µg/L	1	2/5/2020 9:31:03 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200131011-057 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W20 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	1.2	1.0		µg/L	1	2/5/2020 9:34:47 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200131011-058 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W22 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	2.2	1.0		µg/L	1	2/5/2020 9:38:32 PM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200131011-059 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W23 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	ND	1.0		µg/L	1	2/5/2020 9:42:16 PM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200131011-060 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W24 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	1.1	1.0		µg/L	1	2/5/2020 9:46:00 PM
------	-----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 12-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Guilderland High School

LabWork Order: 200131011
PO#:

Lab SampleID: 200131011-061 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W25 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/3/2020)						
Lead	4.4	1.0		µg/L	1	2/5/2020 10:04:42 PM

Lab SampleID: 200131011-062 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W26 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/3/2020)						
Lead	ND	1.0		µg/L	1	2/5/2020 10:15:58 PM

Lab SampleID: 200131011-063 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W27 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/3/2020)						
Lead	2.9	1.0		µg/L	1	2/5/2020 10:19:42 PM

Lab SampleID: 200131011-064 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W28 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/3/2020)						
Lead	ND	1.0		µg/L	1	2/5/2020 10:23:27 PM

Lab SampleID: 200131011-065 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W29 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/3/2020)						
Lead	17.9	1.0	X	µg/L	1	2/5/2020 10:27:11 PM

Adirondack Environmental Services, Inc

Date: 12-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Guilderland High School

LabWork Order: 200131011
PO#:

Lab SampleID: 200131011-066 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W30 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/3/2020)						
Lead	11.3	1.0		µg/L	1	2/5/2020 10:30:56 PM

Lab SampleID: 200131011-067 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W31 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/3/2020)						
Lead	1.4	1.0		µg/L	1	2/5/2020 10:34:41 PM

Lab SampleID: 200131011-068 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W32 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/3/2020)						
Lead	17.1	1.0	X	µg/L	1	2/5/2020 10:45:53 PM

Lab SampleID: 200131011-069 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W33 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/3/2020)						
Lead	11.8	1.0		µg/L	1	2/5/2020 10:49:37 PM

Lab SampleID: 200131011-070 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W34 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/3/2020)						
Lead	1.8	1.0		µg/L	1	2/5/2020 10:53:22 PM

Adirondack Environmental Services, Inc

Date: 12-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Guilderland High School

LabWork Order: 200131011
PO#:

Lab SampleID: 200131011-071 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W35 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: **SM**
(Prep: - 2/3/2020)

Lead	1.7	1.0		µg/L	1	2/5/2020 10:57:07 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 200131011-072 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W36 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: **SM**
(Prep: - 2/3/2020)

Lead	1.4	1.0		µg/L	1	2/5/2020 11:08:23 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 200131011-073 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W37 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: **SM**
(Prep: - 2/3/2020)

Lead	21.8	1.0	X	µg/L	1	2/5/2020 11:12:08 PM
------	------	-----	---	------	---	----------------------

Lab SampleID: 200131011-074 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W38 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: **SM**
(Prep: - 2/3/2020)

Lead	5.2	1.0		µg/L	1	2/5/2020 11:15:52 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 200131011-075 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W39 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: **SM**
(Prep: - 2/3/2020)

Lead	ND	1.0		µg/L	1	2/5/2020 11:19:37 PM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 12-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Guilderland High School

LabWork Order: 200131011
PO#:

Lab SampleID: 200131011-076 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W40 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/3/2020)						
Lead	ND	1.0		µg/L	1	2/5/2020 11:30:50 PM

Lab SampleID: 200131011-077 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W41 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/3/2020)						
Lead	10.4	1.0		µg/L	1	2/5/2020 11:34:34 PM

Lab SampleID: 200131011-078 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W42 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/3/2020)						
Lead	6.7	1.0		µg/L	1	2/5/2020 11:38:19 PM

Lab SampleID: 200131011-079 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W43 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/3/2020)						
Lead	5.4	1.0		µg/L	1	2/5/2020 11:42:04 PM

Lab SampleID: 200131011-080 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W45 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/3/2020)						
Lead	18.9	1.0	X	µg/L	1	2/5/2020 11:45:49 PM

Adirondack Environmental Services, Inc

Date: 12-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Guilderland High School

LabWork Order: 200131011
PO#:

Lab SampleID: 200131011-081 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W46 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/3/2020)						
Lead	8.6	1.0		µg/L	1	2/5/2020 11:57:05 PM

Lab SampleID: 200131011-082 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W47 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/3/2020)						
Lead	5.8	1.0		µg/L	1	2/6/2020 12:15:48 AM

Lab SampleID: 200131011-083 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W48 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/3/2020)						
Lead	4.9	1.0		µg/L	1	2/6/2020 12:19:33 AM

Lab SampleID: 200131011-084 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W49 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/3/2020)						
Lead	1.2	1.0		µg/L	1	2/6/2020 12:23:18 AM

Lab SampleID: 200131011-085 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W51 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/3/2020)						
Lead	2.2	1.0		µg/L	1	2/6/2020 12:27:03 AM

Adirondack Environmental Services, Inc

Date: 12-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Guilderland High School

LabWork Order: 200131011
PO#:

Lab SampleID: 200131011-086 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W52 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/3/2020)						
Lead	1.6	1.0		µg/L	1	2/6/2020 12:30:48 AM

Lab SampleID: 200131011-087 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W53 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/3/2020)						
Lead	ND	1.0		µg/L	1	2/6/2020 12:34:33 AM

Lab SampleID: 200131011-088 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W54 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/3/2020)						
Lead	ND	1.0		µg/L	1	2/6/2020 12:38:19 AM

Lab SampleID: 200131011-089 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W55 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/3/2020)						
Lead	ND	1.0		µg/L	1	2/6/2020 12:42:04 AM

Lab SampleID: 200131011-090 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W56 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/3/2020)						
Lead	ND	1.0		µg/L	1	2/6/2020 12:45:49 AM

Adirondack Environmental Services, Inc

Date: 12-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Guilderland High School

LabWork Order: 200131011
PO#:

Lab SampleID: 200131011-091 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W57 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/3/2020)						
Lead	ND	1.0		µg/L	1	2/6/2020 12:49:35 AM

Lab SampleID: 200131011-092 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W58 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/3/2020)						
Lead	ND	1.0		µg/L	1	2/6/2020 1:08:19 AM

Lab SampleID: 200131011-093 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W59 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/3/2020)						
Lead	7.4	1.0		µg/L	1	2/6/2020 1:12:05 AM

Lab SampleID: 200131011-094 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W61 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/3/2020)						
Lead	1.8	1.0		µg/L	1	2/6/2020 1:15:51 AM

Lab SampleID: 200131011-095 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W62 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/3/2020)						
Lead	2.6	1.0		µg/L	1	2/6/2020 1:19:36 AM

Adirondack Environmental Services, Inc

Date: 12-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Guilderland High School

LabWork Order: 200131011
PO#:

Lab SampleID: 200131011-096 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W63 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	ND	1.0		µg/L	1	2/6/2020 1:23:22 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200131011-097 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W64 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	ND	1.0		µg/L	1	2/6/2020 1:27:07 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200131011-098 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W65 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	ND	1.0		µg/L	1	2/6/2020 1:30:53 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200131011-099 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-W66 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	2.2	1.0		µg/L	1	2/6/2020 1:34:38 AM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200131011-100 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-W67 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	ND	1.0		µg/L	1	2/6/2020 1:45:52 AM
------	----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 12-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Guilderland High School

LabWork Order: 200131011
PO#:

Lab SampleID: 200131011-101 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-W69 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	1.9	1.0		µg/L	1	2/6/2020 1:57:10 AM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200131011-102 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-W70 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	ND	1.0		µg/L	1	2/6/2020 2:08:27 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200131011-103 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-W71 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	ND	1.0		µg/L	1	2/6/2020 2:12:13 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200131011-104 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-W72 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	ND	1.0		µg/L	1	2/6/2020 2:15:59 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200131011-105 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-W73 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	ND	1.0		µg/L	1	2/6/2020 2:19:45 AM
------	----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 12-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Guilderland High School

LabWork Order: 200131011
PO#:

Lab SampleID: 200131011-106 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-W74 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	ND	1.0		µg/L	1	2/6/2020 2:30:59 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200131011-107 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-W75 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	ND	1.0		µg/L	1	2/6/2020 2:34:45 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200131011-108 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-W76 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	ND	1.0		µg/L	1	2/6/2020 2:38:31 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200131011-109 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-W77 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	5.3	1.0		µg/L	1	2/6/2020 2:42:17 AM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200131011-110 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-W78 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	2.8	1.0		µg/L	1	2/6/2020 2:46:03 AM
------	-----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 12-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Guilderland High School

LabWork Order: 200131011
PO#:

Lab SampleID: 200131011-111 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-W79 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	ND	1.0		µg/L	1	2/6/2020 2:49:49 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200131011-112 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-W80 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	ND	1.0		µg/L	1	2/6/2020 3:01:07 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200131011-113 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W81 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	5.2	1.0		µg/L	1	2/6/2020 3:04:54 AM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200131011-114 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W82 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	ND	1.0		µg/L	1	2/6/2020 3:16:08 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200131011-115 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W84 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	ND	1.0		µg/L	1	2/6/2020 3:19:54 AM
------	----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 12-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Guilderland High School

LabWork Order: 200131011
PO#:

Lab SampleID: 200131011-116 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W86 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	ND	1.0		µg/L	1	2/6/2020 3:23:40 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200131011-117 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W87 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	ND	1.0		µg/L	1	2/6/2020 3:27:26 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200131011-118 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W88 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	ND	1.0		µg/L	1	2/6/2020 3:31:12 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200131011-119 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W89 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	ND	1.0		µg/L	1	2/6/2020 3:34:59 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200131011-120 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W90 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	ND	1.0		µg/L	1	2/6/2020 3:38:45 AM
------	----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 12-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Guilderland High School

LabWork Order: 200131011
PO#:

Lab SampleID: 200131011-121 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W91 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	1.5	1.0		µg/L	1	2/6/2020 3:50:04 AM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200131011-122 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W92 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	1.0	1.0		µg/L	1	2/6/2020 4:08:51 AM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200131011-123 **Collection Date:** 1/30/2020
Client Sample ID: GCSD-GHS-W93 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	ND	1.0		µg/L	1	2/6/2020 4:12:38 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200131011-124 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-W94 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	1.9	1.0		µg/L	1	2/6/2020 4:16:24 AM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200131011-125 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-W95 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	1.9	1.0		µg/L	1	2/6/2020 4:20:11 AM
------	-----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 12-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Guilderland High School

LabWork Order: 200131011
PO#:

Lab SampleID: 200131011-126 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-W96 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	3.1	1.0		µg/L	1	2/6/2020 4:23:57 AM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200131011-127 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-W97 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	3.5	1.0		µg/L	1	2/6/2020 4:27:44 AM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200131011-128 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-W101 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	1.4	1.0		µg/L	1	2/6/2020 4:31:30 AM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200131011-129 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-W102 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	2.1	1.0		µg/L	1	2/6/2020 4:35:17 AM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200131011-130 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-W103 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	1.8	1.0		µg/L	1	2/6/2020 4:46:32 AM
------	-----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 12-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Guilderland High School

LabWork Order: 200131011
PO#:

Lab SampleID: 200131011-131 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-W104 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	ND	1.0		µg/L	1	2/6/2020 4:50:18 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200131011-132 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-W105 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	ND	1.0		µg/L	1	2/6/2020 5:01:38 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200131011-133 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-W106 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	5.0	1.0		µg/L	1	2/6/2020 5:05:25 AM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200131011-134 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-W107 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	2.8	1.0		µg/L	1	2/6/2020 5:09:12 AM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200131011-135 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-W108 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	1.2	1.0		µg/L	1	2/6/2020 5:12:59 AM
------	-----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 12-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Guilderland High School

LabWork Order: 200131011
PO#:

Lab SampleID: 200131011-136 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-W109 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	ND	1.0		µg/L	1	2/6/2020 5:16:45 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200131011-137 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-W110 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	ND	1.0		µg/L	1	2/6/2020 5:20:32 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200131011-138 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-W111 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	ND	1.0		µg/L	1	2/6/2020 5:31:47 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200131011-139 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-W112 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	ND	1.0		µg/L	1	2/6/2020 5:35:35 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200131011-140 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-W113 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	ND	1.0		µg/L	1	2/6/2020 5:39:22 AM
------	----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 12-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Guilderland High School

LabWork Order: 200131011
PO#:

Lab SampleID: 200131011-141 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-W114 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	ND	1.0		µg/L	1	2/6/2020 5:50:43 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200131011-142 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-W115 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	ND	1.0		µg/L	1	2/6/2020 6:02:06 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200131011-143 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-W116 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	ND	1.0		µg/L	1	2/6/2020 6:05:53 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200131011-144 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-W117 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	ND	1.0		µg/L	1	2/6/2020 6:17:08 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200131011-145 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-W119 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	ND	1.0		µg/L	1	2/6/2020 6:20:55 AM
------	----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 12-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Guilderland High School

LabWork Order: 200131011
PO#:

Lab SampleID: 200131011-146 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-W120 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	ND	1.0		µg/L	1	2/6/2020 6:24:43 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200131011-147 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-W121 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	2.6	1.0		µg/L	1	2/6/2020 6:28:30 AM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200131011-148 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-W122 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	ND	1.0		µg/L	1	2/6/2020 6:32:18 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200131011-149 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-W123 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	12.4	1.0		µg/L	1	2/6/2020 6:36:05 AM
------	------	-----	--	------	---	---------------------

Lab SampleID: 200131011-150 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-W124 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	8.2	1.0		µg/L	1	2/6/2020 6:39:53 AM
------	-----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 12-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Guilderland High School

LabWork Order: 200131011
PO#:

Lab SampleID: 200131011-151 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-W125 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	9.0	1.0		µg/L	1	2/6/2020 6:43:40 AM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200131011-152 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-W126 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	6.0	1.0		µg/L	1	2/6/2020 7:02:31 AM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200131011-153 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-W128 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	9.1	1.0		µg/L	1	2/6/2020 7:06:19 AM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200131011-154 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-W129 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	ND	1.0		µg/L	1	2/6/2020 7:10:06 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200131011-155 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-W130 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	ND	1.0		µg/L	1	2/6/2020 7:13:54 AM
------	----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 12-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Guilderland High School

LabWork Order: 200131011
PO#:

Lab SampleID: 200131011-156 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-W131 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	ND	1.0		µg/L	1	2/6/2020 7:17:42 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200131011-157 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-W134 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	ND	1.0		µg/L	1	2/6/2020 7:21:29 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200131011-158 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-W135 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	3.8	1.0		µg/L	1	2/6/2020 7:25:17 AM
------	-----	-----	--	------	---	---------------------

Lab SampleID: 200131011-159 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-W65A **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	ND	1.0		µg/L	1	2/6/2020 7:29:05 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200131011-160 **Collection Date:** 1/31/2020
Client Sample ID: GCSD-GHS-W119A **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: SM
(Prep: - 2/3/2020)

Lead	2.1	1.0		µg/L	1	2/6/2020 7:32:53 AM
------	-----	-----	--	------	---	---------------------

Adirondack Environmental Services, Inc

Date: 12-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Guilderland High School

LabWork Order: 200131011
PO#:

Lab SampleID: 200131011-161
Client Sample ID: GCSD-GHS-W120A

Collection Date: 1/31/2020
Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 2/3/2020)

Lead	ND	1.0		µg/L	1	2/6/2020 7:51:44 AM
------	----	-----	--	------	---	---------------------

Lab SampleID: 200131011-162
Client Sample ID: GCSD-GHS-E29A

Collection Date: 1/31/2020
Matrix: DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4

Analyst: SM

(Prep: - 2/3/2020)

Lead	ND	1.0		µg/L	1	2/6/2020 8:03:08 AM
------	----	-----	--	------	---	---------------------



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#:

200131011

COC Reference:

1378

A full service analytical research laboratory offering solutions to environmental concerns

GCSD		Address:							
Send Report to:		Project Name (Location): Guilderland High School				Samplers Name: <i>Ryan Bursley</i>			
Client Phone #:		Client PO #:				Samplers Signature: <i>[Signature]</i>			
Client Email:									
AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
001	GCSD-GHS-E01	1/30/2020	0650	PW		X	1	0	Lead
002	GCSD-GHS-E02	1/30/2020	0648	PW		X	1	0	Lead
003	GCSD-GHS-E03	1/31/2020	0609	PW		X	1	0	Lead
004	GCSD-GHS-E05	1/31/2020	0539	PW		X	1	0	Lead
005	GCSD-GHS-E06	1/31/2020	0538	PW		X	1	0	Lead
006	GCSD-GHS-E07	1/31/2020	0538	PW		X	1	0	Lead
007	GCSD-GHS-E08	1/31/2020	0538	PW		X	1	0	Lead
008	GCSD-GHS-E09	1/31/2020	0538	PW		X	1	0	Lead
009	GCSD-GHS-E10	1/31/2020	0538	PW		X	1	0	Lead
010	GCSD-GHS-E11	1/31/2020	0538	PW		X	1	0	Lead
011	GCSD-GHS-E12	1/31/2020	0538	PW		X	1	0	Lead
012	GCSD-GHS-E13	1/31/2020	0540	PW		X	1	0	Lead
013	GCSD-GHS-E14	1/30/2020	0520	PW		X	1	0	Lead
014	GCSD-GHS-E15	1/30/2020	0520	PW		X	1	0	Lead
015	GCSD-GHS-E16	1/30/2020	0520	PW		X	1	0	Lead
016	GCSD-GHS-E17	1/31/2020	0540	PW		X	1	0	Lead
Shipment Arrived Via: FedEx UPS Client <u>AES</u> Other:				Special Instructions/Remarks:					
Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day Standard									
NOTE: Samples received after 3:30pm are considered next business day.									
Relinquished by: (Signature)				Received by: (Signature)				Date	Time
Relinquished by: (Signature)				Received by: (Signature)				Date	Time
Relinquished by: (Signature)				Received for Laboratory by:				Date	Time
Sample Temperature Ambient Notes: Ice preservation not required				Properly Preserved: <u>Y</u> / N 0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 3=HCl pH<2 4=Na ₂ S ₂ O ₃ 5=NH ₄ Cl 6=Ascorbic Acid 7=FAS 8=ZnAc/Ni 9=NaOH p 10=Other_				Received Within Holding Times: <u>Y</u> / N	
Bottles AES: <u>Y</u> / N								Notes: 	



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#:

200131011

COC Reference:

1378

A full service analytical research laboratory offering solutions to environmental concerns

GCSD		Address:							
Send Report to:		Project Name (Location): Guiderland High School			Samplers Name: Ryan Baitsky				
Client Phone #:		Client PO #:			Samplers Signature: 				
Client Email:									
AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
017	GCSD-GHS-E18	1/30/2020	0510	PW		X	1	0	Lead
018	GCSD-GHS-E29	1/30/2020	0525	PW		X	1	0	Lead
019	GCSD-GHS-E41	1/30/2020	0526	PW		X	1	0	Lead
020	GCSD-GHS-E42	1/30/2020	0527	PW		X	1	0	Lead
021	GCSD-GHS-E43	1/30/2020	0512	PW		X	1	0	Lead
022	GCSD-GHS-E44	1/30/2020	0510	PW		X	1	0	Lead
023	GCSD-GHS-E95			PW		X	1	0	Lead
024	GCSD-GHS-E96	1/30/2020	0514	PW		X	1	0	Lead
025	GCSD-GHS-E97	1/30/2020	0514	PW		X	1	0	Lead
026	GCSD-GHS-E98	1/30/2020	0516	PW		X	1	0	Lead
027	GCSD-GHS-E99	1/30/2020	0516	PW		X	1	0	Lead
028	GCSD-GHS-E100	1/30/2020	0516	PW		X	1	0	Lead
029	GCSD-GHS-E101			PW		X	1	0	Lead
030	GCSD-GHS-E168	1/30/2020	0503	PW		X	1	0	Lead
031	GCSD-GHS-E169	1/30/2020	0504	PW		X	1	0	Lead
032	GCSD-GHS-E170	1/30/2020	0505	PW		X	1	0	Lead

Shipment Arrived Via: FedEx UPS Client <u>AES</u> Other: _____		Special Instructions/Remarks:			
Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day Standard					
NOTE: Samples received after 3:30pm are considered next business day.					
		PLEASE FILL ALL PINK SHADED AREAS			
Relinquished by: (Signature)		Received by: (Signature)		Date	Time
Relinquished by: (Signature)		Received by: (Signature)		Date	Time
Relinquished by: (Signature)		Received for Laboratory by:		Date	Time
				1/31/20	1032am

Sample Temperature Ambient Notes: Ice preservation not required	Properly Preserved: Y / N	Received Within Holding Times: Y / N Notes:
	Bottles AES: Y / N	
	0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 3=HCl pH<2 4=Na ₂ S ₂ O ₃	5=NH ₄ Cl 6=Ascorbic Acid 7=FAS 8=ZnAc/NaOH pH>9 9=NaOH pH>10 10=Other _____



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#:

200131011

COC Reference:

1378

A full service analytical research laboratory offering solutions to environmental concerns

GCSD		Address:							
Send Report to:		Project Name (Location): Guilderland High School			Samplers Name: Ryan Baisley				
Client Phone #:		Client PO #:			Samplers Signature:				
Client Email:									
AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
033	GCSD-GHS-E171			PW		X	1	0	Lead
034	GCSD-GHS-E172			PW		X	1	0	Lead
035	GCSD-GHS-E173			PW		X	1	0	Lead
036	GCSD-GHS-E174	1/30/2020	0510	PW		X	1	0	Lead
037	GCSD-GHS-E175			PW		X	1	0	Lead
038	GCSD-GHS-E176	1/30/2020	512	PW		X	1	0	Lead
039	GCSD-GHS-E177			PW		X	1	0	Lead
040	GCSD-GHS-E178			PW		X	1	0	Lead
041	GCSD-GHS-E179			PW		X	1	0	Lead
042	GCSD-GHS-E180	1/31/2020	0515	PW		X	1	0	Lead
043	GCSD-GHS-E185	1/31/2020	0540	PW		X	1	0	Lead
044	GCSD-GHS-E41B	1/30/2020	0528	PW		X	1	0	Lead
045	GCSD-GHS-E42A	1/30/2020	0528	PW		X	1	0	Lead
046	GCSD-GHS-E42C	1/30/2020	0528	PW		X	1	0	Lead
Shipment Arrived Via: FedEx UPS Client <u>AES</u> Other:				Special Instructions/Remarks:					
Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day Standard									
NOTE: Samples received after 3:30pm are considered next business day.									
Relinquished by: (Signature)				Received by: (Signature)				Date	Time
Relinquished by: (Signature)				Received by: (Signature)				Date	Time
Relinquished by: (Signature)				Received for Laboratory by:				Date	Time
Sample Temperature Ambient Notes: Ice preservation not required				Properly Preserved: <u>Y</u> / N 0=None 5=NH ₄ Cl 1=H ₂ SO ₄ pH<2 6=Ascorbic Acid 2=HNO ₃ pH<2 7=FAS 3=HCl pH<2 8=ZnAc/NaOH pH>9 4=Na ₂ S ₂ O ₃ 9=NaOH pH>10 10=Other				Received Within Holding Times: <u>Y</u> / N Notes:	
Bottles AES: <u>Y</u> / N									



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#:

200131011

COC Reference:

1378

A full service analytical research laboratory offering solutions to environmental concerns

GCSD		Address:							
Send Report to:		Project Name (Location): Guilderland High School			Samplers Name: Ryan Baisley				
Client Phone #:		Client PO #:			Samplers Signature: [Signature]				
Client Email:									
AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
047	GCSD-GHS-W01	1/30/2020	0613	PW		X	1	0	Lead
048	GCSD-GHS-W02	1/30/2020	0620	PW		X	1	0	Lead
049	GCSD-GHS-W03	1/30/2020	0612	PW		X	1	0	Lead
050	GCSD-GHS-W04	1/30/2020	0612	PW		X	1	0	Lead
051	GCSD-GHS-W05	1/30/2020	0612	PW		X	1	0	Lead
052	GCSD-GHS-W06	1/30/2020	0612	PW		X	1	0	Lead
053	GCSD-GHS-W07	1/30/2020	0610	PW		X	1	0	Lead
054	GCSD-GHS-W08	1/30/2020	0610	PW		X	1	0	Lead
055	GCSD-GHS-W09	1/30/2020	0610	PW		X	1	0	Lead
056	GCSD-GHS-W10	1/30/2020	0610	PW		X	1	0	Lead
057	GCSD-GHS-W11	1/30/2020	0615	PW		X	1	0	Lead
058	GCSD-GHS-W12	1/30/2020	0615	PW		X	1	0	Lead
059	GCSD-GHS-W13	1/30/2020	0615	PW		X	1	0	Lead
060	GCSD-GHS-W14	1/30/2020	0615	PW		X	1	0	Lead
061	GCSD-GHS-W15	1/30/2020	0615	PW		X	1	0	Lead
062	GCSD-GHS-W16	1/30/2020	0618	PW		X	1	0	Lead
Shipment Arrived Via: FedEx UPS Client <u>AES</u> Other:				Special Instructions/Remarks:					
Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day Standard									
NOTE: Samples received after 3:30pm are considered next business day.									
Relinquished by: (Signature)				Received by: (Signature)				Date	Time
Relinquished by: (Signature)				Received by: (Signature)				Date	Time
Relinquished by: (Signature)				Received for Laboratory by:				Date	Time
Sample Temperature Ambient Notes: Ice preservation not required				Properly Preserved: Y / N 0=None 5=NH ₄ Cl 1=H ₂ SO ₄ pH<2 6=Ascorbic Acid 2=HNO ₃ pH<2 7=FAS 3=HCl pH<2 8=ZnAc/NaOH pH>9 4=Na ₂ S ₂ O ₃ 9=NaOH pH>10 10=Other				Received Within Holding Times: Y / N	
Bottles AES: Y / N								Notes:	



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#:

200131011

COC Reference:

1378

A full service analytical research laboratory offering solutions to environmental concerns

GCSD		Address:							
Send Report to:		Project Name (Location): Guilderland High School			Samplers Name: Ryan Baubley				
Client Phone #:		Client PO #:			Samplers Signature:				
Client Email:									
AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
063	GCSD-GHS-W17	1/30/2020	0618	PW		X	1	0	Lead
064	GCSD-GHS-W18	1/30/2020	0618	PW		X	1	0	Lead
065	GCSD-GHS-W19	1/30/2020	0611	PW		X	1	0	Lead
066	GCSD-GHS-W20	1/30/2020	0611	PW		X	1	0	Lead
067	GCSD-GHS-W21		06	PW		X	1	0	Lead
068	GCSD-GHS-W22	1/30/2020	0612	PW		X	1	0	Lead
069	GCSD-GHS-W23	1/30/2020	0612	PW		X	1	0	Lead
070	GCSD-GHS-W24	1/30/2020	0612	PW		X	1	0	Lead
071	GCSD-GHS-W25	1/30/2020	608	PW		X	1	0	Lead
072	GCSD-GHS-W26	1/30/2020	608	PW		X	1	0	Lead
073	GCSD-GHS-W27	1/30/2020	608	PW		X	1	0	Lead
074	GCSD-GHS-W28	1/30/2020	0608	PW		X	1	0	Lead
075	GCSD-GHS-W29	1/30/2020	0616	PW		X	1	0	Lead
076	GCSD-GHS-W30	1/30/2020	0617	PW		X	1	0	Lead
077	GCSD-GHS-W31	1/30/2020	0542	PW		X	1	0	Lead
078	GCSD-GHS-W32	1/30/2020	0540	PW		X	1	0	Lead
Shipment Arrived Via: FedEx UPS Client AES Other:				Special Instructions/Remarks:					
Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day Standard NOTE: Samples received after 3:30pm are considered next business day.				PLEASE FILL ALL PINK SHADED AREAS					
Relinquished by: (Signature)				Received by: (Signature)				Date	Time
Relinquished by: (Signature)				Received by: (Signature)				Date	Time
Relinquished by: (Signature)				Received for Laboratory by:				Date	Time
Sample Temperature Ambient Notes: Ice preservation not required				Properly Preserved: Y / N 0=None 5=NH ₄ Cl 1=H ₂ SO ₄ pH<2 6=Ascorbic Acid 2=HNO ₃ pH<2 7=FAS 3=HCl pH<2 8=ZnAc/NaOH pH>9 4=Na ₂ S ₂ O ₃ 9=NaOH pH>10 10=Other				Received Within Holding Times: Y / N Notes:	
Bottles AES: Y / N									



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#:

200131011

COC Reference:

1378

A full service analytical research laboratory offering solutions to environmental concerns

GCSD		Address:							
Send Report to:		Project Name (Location): Guilderland High School			Samplers Name: Ryan Bairstey				
Client Phone #:		Client PO #:			Samplers Signature: [Signature]				
Client Email:									
AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
079	GCSD-GHS-W32	1/30/2020	0540	PW		X	1	0	Lead
080	GCSD-GHS-W33	1/30/2020	0540	PW		X	1	0	Lead
081	GCSD-GHS-W34	1/30/2020	0540	PW		X	1	0	Lead
082	GCSD-GHS-W35	1/30/2020	0538	PW		X	1	0	Lead
083	GCSD-GHS-W36	1/30/2020	0538	PW		X	1	0	Lead
084	GCSD-GHS-W37	1/30/2020	0542	PW		X	1	0	Lead
085	GCSD-GHS-W38	1/30/2020	0544	PW		X	1	0	Lead
086	GCSD-GHS-W39	1/30/2020	0535	PW		X	1	0	Lead
087	GCSD-GHS-W40	1/30/2020	0535	PW		X	1	0	Lead
088	GCSD-GHS-W41	1/30/2020	0545	PW		X	1	0	Lead
089	GCSD-GHS-W42	1/30/2020	0545	PW		X	1	0	Lead
090	GCSD-GHS-W43	1/30/2020	0545	PW		X	1	0	Lead
091	GCSD-GHS-W44	1/30/2020	0546	PW		X	1	0	Lead
092	GCSD-GHS-W45	1/30/2020	0546	PW		X	1	0	Lead
093	GCSD-GHS-W46	1/30/2020	0546	PW		X	1	0	Lead
094	GCSD-GHS-W47	1/30/2020	0547	PW		X	1	0	Lead

Shipment Arrived Via: FedEx UPS Client AES Other:		Special Instructions/Remarks:		
Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day Standard				
NOTE: Samples received after 3:30pm are considered next business day.				
Relinquished by: (Signature)		Received by: (Signature)	Date	Time
Relinquished by: (Signature)		Received by: (Signature)	Date	Time
Relinquished by: (Signature)		Received for Laboratory by:	Date	Time

Sample Temperature Ambient Notes: Ice preservation not required	Properly Preserved: Y / N 0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 3=HCl pH<2 4=Na ₂ S ₂ O ₃ 5=NH ₄ Cl 6=Ascorbic Acid 7=FAS 8=ZnAc/NaOH pH>9 9=NaOH pH>10 10=Other	Received Within Holding Times: Y / N Notes:
Bottles AES: Y / N		



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#:

200131011

COC Reference:

1378

A full service analytical research laboratory offering solutions to environmental concerns

GCSD		Address:							
Send Report to:		Project Name (Location): Guilderland High School			Samplers Name: <i>Ryan Baishley</i>				
Client Phone #:		Client PO #:			Samplers Signature: <i>[Signature]</i>				
Client Email:									
AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
095	GCSD-GHS-W48	1/30/2020	0548	PW		X	1	0	Lead
096	GCSD-GHS-W49	1/30/2020	0550	PW		X	1	0	Lead
097	GCSD-GHS-W50	1/30/2020	0552	PW		X	1	0	Lead
098	GCSD-GHS-W51	1/30/2020	0552	PW		X	1	0	Lead
099	GCSD-GHS-W52	1/30/2020	0552	PW		X	1	0	Lead
100	GCSD-GHS-W53	1/30/2020	0555	PW		X	1	0	Lead
101	GCSD-GHS-W54	1/30/2020	0555	PW		X	1	0	Lead
102	GCSD-GHS-W55	1/30/2020	0555	PW		X	1	0	Lead
103	GCSD-GHS-W56	1/30/2020	0602	PW		X	1	0	Lead
104	GCSD-GHS-W57	1/30/2020	0602	PW		X	1	0	Lead
105	GCSD-GHS-W58	1/30/2020	0558	PW		X	1	0	Lead
106	GCSD-GHS-W59	1/30/2020	0600	PW		X	1	0	Lead
107	GCSD-GHS-W60	1/30/2020	0600	PW		X	1	0	Lead
108	GCSD-GHS-W61	1/30/2020	0600	PW		X	1	0	Lead
109	GCSD-GHS-W62	1/30/2020	0605	PW		X	1	0	Lead
110	GCSD-GHS-W63	1/30/2020	0606	PW		X	1	0	Lead

Shipment Arrived Via: FedEx UPS Client AES Other:		Special Instructions/Remarks:		
Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day Standard				
NOTE: Samples received after 3:30pm are considered next business day.				
Relinquished by: (Signature)		Received by: (Signature)	Date	Time
Relinquished by: (Signature)		Received by: (Signature)	Date	Time
Relinquished by: (Signature)		Received for Laboratory by:	Date	Time
<i>[Signature]</i>		<i>[Signature]</i>	1/31/20	1032am

Sample Temperature Ambient Notes: Ice preservation not required	Properly Preserved: Y / N 0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 3=HCl pH<2 4=Na ₂ S ₂ O ₃ 5=NH ₄ Cl 6=Ascorbic Acid 7=FAS 8=ZnAc/NaOH pH>9 9=NaOH pH>10 10=Other	Received Within Holding Times: Y / N Notes:



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#:

200131011

COC Reference:

1378

A full service analytical research laboratory offering solutions to environmental concerns

GCSD		Address:							
Send Report to:		Project Name (Location): Guilderland High School			Samplers Name: Ryan Bailely				
Client Phone #:		Client PO #:			Samplers Signature: [Signature]				
Client Email:									
AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
111	GCSD-GHS-W64	1/30/2020	0607	PW		X	1	0	Lead
112	GCSD-GHS-W65	1/30/2020	0602	PW		X	1	0	Lead
113	GCSD-GHS-W66	1/31/2020	0637	PW		X	1	0	Lead
114	GCSD-GHS-W67	1/31/2020	0637	PW		X	1	0	Lead
115	GCSD-GHS-W68	1/31/2020	0637	PW		X	1	0	Lead
116	GCSD-GHS-W69	1/31/2020	0638	PW		X	1	0	Lead
117	GCSD-GHS-W70	1/31/2020	0638	PW		X	1	0	Lead
118	GCSD-GHS-W71	1/31/2020	0638	PW		X	1	0	Lead
119	GCSD-GHS-W72	1/31/2020	0650	PW		X	1	0	Lead
120	GCSD-GHS-W73	1/31/2020	0650	PW		X	1	0	Lead
121	GCSD-GHS-W74	1/31/2020	0652	PW		X	1	0	Lead
122	GCSD-GHS-W75	1/31/2020	0652	PW		X	1	0	Lead
123	GCSD-GHS-W76	1/31/2020	0652	PW		X	1	0	Lead
124	GCSD-GHS-W77	1/31/2020	0615	PW		X	1	0	Lead
125	GCSD-GHS-W78	1/31/2020	0615	PW		X	1	0	Lead
126	GCSD-GHS-W79	1/31/2020	0616	PW		X	1	0	Lead

Shipment Arrived Via: FedEx UPS Client AES Other:		Special Instructions/Remarks:		
Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day Standard NOTE: Samples received after 3:30pm are considered next business day.				
Relinquished by: (Signature)		Received by: (Signature)	Date	Time
Relinquished by: (Signature)		Received by: (Signature)	Date	Time
Relinquished by: (Signature)		Received for Laboratory by:	Date	Time
[Signature]		[Signature]	7/31/20	1032am

Sample Temperature Ambient Notes: Ice preservation not required	Properly Preserved: Y / N 0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 3=HCl pH<2 4=Na ₂ S ₂ O ₃ 5=NH ₄ Cl 6=Ascorbic Acid 7=FAS 8=ZnAc/NaOH pH>9 9=NaOH pH>10 10=Other	Received Within Holding Times: Y / N Notes:
Bottles AES: Y / N		



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#:

200131011

COC Reference:

1378

A full service analytical research laboratory offering solutions to environmental concerns

GCSD		Address:							
Send Report to:		Project Name (Location): Guilderland High School				Samplers Name: Ryan Bausley			
Client Phone #:		Client PO #:				Samplers Signature: [Signature]			
Client Email:									
AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
127	GCSD-GHS-W80	1/31/2020	0609	PW		X	1	0	Lead
128	GCSD-GHS-W81	1/30/2020	0630	PW		X	1	0	Lead
129	GCSD-GHS-W82	1/30/2020	0631	PW		X	1	0	Lead
130	GCSD-GHS-W83	1/30/2020		PW		X	1	0	Lead
131	GCSD-GHS-W84	1/30/2020	0631	PW		X	1	0	Lead
132	GCSD-GHS-W85	1/30/2020		PW		X	1	0	Lead
133	GCSD-GHS-W86	1/30/2020	0635	PW		X	1	0	Lead
134	GCSD-GHS-W87	1/30/2020	0635	PW		X	1	0	Lead
135	GCSD-GHS-W88	1/30/2020	0640	PW		X	1	0	Lead
136	GCSD-GHS-W89	1/30/2020	0640	PW		X	1	0	Lead
137	GCSD-GHS-W90	1/30/2020	0640	PW		X	1	0	Lead
138	GCSD-GHS-W91	1/30/2020	0640	PW		X	1	0	Lead
139	GCSD-GHS-W92	1/30/2020	0636	PW		X	1	0	Lead
140	GCSD-GHS-W93	1/30/2020	0632	PW		X	1	0	Lead
141	GCSD-GHS-W94	1/31/2020	0635	PW		X	1	0	Lead
142	GCSD-GHS-W95	1/31/2020	0635	PW		X	1	0	Lead

Shipment Arrived Via: FedEx UPS Client AES Other:		Special Instructions/Remarks:		
Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day Standard				
NOTE: Samples received after 3:30pm are considered next business day.				
Relinquished by: (Signature)		Received by: (Signature)	Date	Time
Relinquished by: (Signature)		Received by: (Signature)	Date	Time
Relinquished by: (Signature)		Received for Laboratory by:	Date	Time

Sample Temperature Ambient Notes: Ice preservation not required	Properly Preserved: Y / N 0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 3=HCl pH<2 4=Na ₂ S ₂ O ₃ 5=NH ₄ Cl 6=Ascorbic Acid 7=FAS 8=ZnAc/NaOH pH>9 9=NaOH pH>10 10=Other	Received Within Holding Times: Y / N Notes:



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#:

200131011

COC Reference:

1378

A full service analytical research laboratory offering solutions to environmental concerns

GCSD		Address:							
Send Report to:		Project Name (Location): Guilderland High School			Samplers Name: <i>Ryan Bairstey</i>				
Client Phone #:		Client PO #:			Samplers Signature: <i>[Signature]</i>				
Client Email:									
AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
24 143	GCSD-GHS-W96	1/31/2020	0635	PW		X	1	0	Lead
25 144	GCSD-GHS-W97	1/31/2020	0635	PW		X	1	0	Lead
145	GCSD-GHS-W98	1/31/2020		PW		X	1	0	Lead
146	GCSD-GHS-W99	1/31/2020		PW		X	1	0	Lead
147	GCSD-GHS-W100	1/31/2020		PW		X	1	0	Lead
26 148	GCSD-GHS-W101	1/31/2020	0555	PW		X	1	0	Lead
27 149	GCSD-GHS-W102	1/31/2020	0600	PW		X	1	0	Lead
28 150	GCSD-GHS-W103	1/31/2020	0610	PW		X	1	0	Lead
29 151	GCSD-GHS-W104	1/31/2020	0610	PW		X	1	0	Lead
30 152	GCSD-GHS-W105	1/31/2020	0610	PW		X	1	0	Lead
31 153	GCSD-GHS-W106	1/31/2020	0610	PW		X	1	0	Lead
32 154	GCSD-GHS-W107	1/31/2020	0610	PW		X	1	0	Lead
33 155	GCSD-GHS-W108	1/31/2020	0610	PW		X	1	0	Lead
34 156	GCSD-GHS-W109	1/31/2020	0611	PW		X	1	0	Lead
35 157	GCSD-GHS-W110	1/31/2020	0611	PW		X	1	0	Lead
36 158	GCSD-GHS-W111	1/31/2020	0611	PW		X	1	0	Lead

Shipment Arrived Via: FedEx UPS Client AES Other:		Special Instructions/Remarks:			
Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day Standard					
NOTE: Samples received after 3:30pm are considered next business day.					
		PLEASE FILL ALL PINK SHADED AREAS			
Relinquished by: (Signature)		Received by: (Signature)		Date	Time
Relinquished by: (Signature)		Received by: (Signature)		Date	Time
Relinquished by: (Signature)		Received for Laboratory by:		Date	Time
		<i>King</i>		1/31/20	1032am

Sample Temperature Ambient Notes: Ice preservation not required	Properly Preserved: Y / N 0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 3=HCl pH<2 4=Na ₂ S ₂ O ₃ 5=NH ₄ Cl 6=Ascorbic Acid 7=FAS 8=ZnAc/NaOH pH>9 9=NaOH pH>10 10=Other	Received Within Holding Times: Y / N Notes:



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#:

200131011

COC Reference:

1378

A full service analytical research laboratory offering solutions to environmental concerns

GCSD		Address:							
Send Report to:		Project Name (Location): Guilderland High School			Samplers Name: <i>Ryan Bailey</i>				
Client Phone #:		Client PO #:			Samplers Signature: <i>[Signature]</i>				
Client Email:									
AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
37 159	GCSD-GHS-W112	1/31/2020	0611	PW		X	1	0	Lead
38 160	GCSD-GHS-W113	1/31/2020	0611	PW		X	1	0	Lead
39 161	GCSD-GHS-W114	1/31/2020	0615	PW		X	1	0	Lead
40 162	GCSD-GHS-W115	1/31/2020	0615	PW		X	1	0	Lead
41 163	GCSD-GHS-W116	1/31/2020	0615	PW		X	1	0	Lead
42 164	GCSD-GHS-W117	1/31/2020	0615	PW		X	1	0	Lead
	165 GCSD-GHS-W118			PW		X	1	0	Lead
43 166	GCSD-GHS-W119	1/31/2020	0650	PW		X	1	0	Lead
44 167	GCSD-GHS-W120	1/31/2020	0558	PW		X	1	0	Lead
45 168	GCSD-GHS-W121	1/31/2020	0556	PW		X	1	0	Lead
46 169	GCSD-GHS-W122	1/31/2020	0659	PW		X	1	0	Lead
47 170	GCSD-GHS-W123	1/31/2020	0602	PW		X	1	0	Lead
48 171	GCSD-GHS-W124	1/31/2020	0602	PW		X	1	0	Lead
49 172	GCSD-GHS-W125	1/31/2020	0602	PW		X	1	0	Lead
50 173	GCSD-GHS-W126	1/31/2020	0603	PW		X	1	0	Lead
51 174	GCSD-GHS-W127	1/31/2020	0603	PW		X	1	0	Lead
Shipment Arrived Via: FedEx UPS Client AES Other: _____				Special Instructions/Remarks:					
Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day Standard									
NOTE: Samples received after 3:30pm are considered next business day.									
				PLEASE FILL ALL PINK SHADED AREAS					
Relinquished by: (Signature)				Received by: (Signature)				Date	Time
Relinquished by: (Signature)				Received by: (Signature)				Date	Time
Relinquished by: (Signature) <i>[Signature]</i>				Received for Laboratory by: <i>[Signature]</i>				Date 1/31/20	Time 1032am
Sample Temperature Ambient Notes: Ice preservation not required		Properly Preserved: Y / N 0=None 5=NH ₄ Cl 1=H ₂ SO ₄ pH<2 6=Ascorbic Acid 2=HNO ₃ pH<2 7=FAS 3=HCl pH<2 8=ZnAc/NaOH pH>9 4=Na ₂ S ₂ O ₃ 9=NaOH pH>10 10=Other _____				Received Within Holding Times: Y / N Notes:			
Bottles AES: Y / N									



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#:

200131011

COC Reference:

1378

A full service analytical research laboratory offering solutions to environmental concerns

GCSD		Address:							
Send Report to:		Project Name (Location): Guilderland High School				Samplers Name: <i>Zepan Bausley</i>			
Client Phone #:		Client PO #:				Samplers Signature: <i>[Signature]</i>			
Client Email:									
AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
175	GCSD-GHS-W128	1/31/2020		PW		X	1	0	Lead
176	GCSD-GHS-W129	1/31/2020		PW		X	1	0	Lead
177	GCSD-GHS-W130	1/31/2020		PW		X	1	0	Lead
178	GCSD-GHS-W131	1/31/2020		PW		X	1	0	Lead
179	GCSD-GHS-W132			PW		X	1	0	Lead
180	GCSD-GHS-W133			PW		X	1	0	Lead
181	GCSD-GHS-W134	1/31/2020	0606	PW		X	1	0	Lead
182	GCSD-GHS-W135	1/31/2020	0600	PW		X	1	0	Lead
183	GCSD-GHS-W136A	1/31/2020	0602	PW		X	1	0	Lead
184	GCSD-GHS-W119A	1/31/2020	0650	PW		X	1	0	Lead
185	GCSD-GHS-W120A	1/31/2020	0558	PW		X	1	0	Lead
186	GCSD-GHS-W121A	1/31/2020	0525	PW		X	1	0	Lead
Shipment Arrived Via:		Special Instructions/Remarks:							
FedEx UPS Client AES Other:									
Turnaround Time Requested:									
1 Day 2 Day 3 Day 5 Day Standard									
NOTE: Samples received after 3:30pm are considered next business day.		PLEASE FILL ALL PINK SHADED AREAS							
Relinquished by: (Signature)		Received by: (Signature)						Date	Time
Relinquished by: (Signature)		Received by: (Signature)						Date	Time
Relinquished by: (Signature)		Received for Laboratory by:						Date	Time
Sample Temperature		Properly Preserved: Y / N						Received Within Holding Times: Y / N	
Ambient		0=None 5=NH ₄ Cl						Notes:	
Notes: Ice preservation not required		1=H ₂ SO ₄ pH<2 6=Ascorbic Acid							
		2=HNO ₃ pH<2 7=FAS							
		3=HCl pH<2 8=ZnAc/NaOH pH>9							
		4=Na ₂ S ₂ O ₃ 9=NaOH pH>10							
		10=Other							
Bottles AES: Y / N									



Experience is the solution

314 North Pearl Street • Albany, New York 12207 • (518) 434-4546 • Fax (518) 434-0891

TERMS, CONDITIONS & LIMITATIONS

All service rendered by the **Adirondack Environmental Services, Inc.** are undertaken and all rates are based upon the following terms:

- (a) Neither **Adirondack Environmental Services, Inc.**, nor any of its employees, agents or sub-contractors shall be liable for any loss or damage arising out of **Adirondack Environmental Services, Inc.**'s performance or nonperformance, whether by way of negligence or breach of contract, or otherwise, in any amount greater than twice the amount billed to the customer for the work leading to the claim of the customer. Said remedy shall be the sole and exclusive remedy against **Adirondack Environmental Services, Inc.** arising out of its work.
- (b) All claims made must be in writing within forty-five (45) days after delivery of the **Adirondack Environmental Services, Inc.** report regarding said work or such claim shall be deemed or irrevocably waived.
- (c) **Adirondack Environmental Services, Inc.** reports are submitted in writing and are for our customers only. Our customers are considered to be only those entities being billed for our services. Acquisition of an **Adirondack Environmental Services, Inc.** report by other than our customer does not constitute a representation of **Adirondack Environmental Services, Inc.** as to the accuracy of the contents thereof.
- (d) In no event shall **Adirondack Environmental Services, Inc.**, its employees, agents or sub-contractors be responsible for consequential or special damages of any kind or in any amount.
- (e) No deviation from the terms set forth herein shall bind **Adirondack Environmental Services, Inc.** unless in writing and signed by a Director of **Adirondack Environmental Services, Inc.**
- (f) Results pertain only to items analyzed. Information supplied by client is assumed to be correct. This information may be used on reports and in calculations and **Adirondack Environmental Services, Inc.** is not responsible for the accuracy of this information.
- (g) Payments by Credit Card/Purchase Cards are subject to a 3% additional charge.