



Experience is the solution

314 North Pearl Street ♦ Albany, New York 12207
(800) 848-4983 ♦ (518) 434-4546 ♦ Fax (518) 434-0891

February 20, 2020

Clifford Nooney
Guilderland CSD
PO Box 381
Guilderland Center, NY 12085
TEL: (518) 456-6200

Work Order No: 200207028
PO#: 197320

RE: 2020 Lead Sampling and Analysis
Pine Bush Elementary

Dear Clifford Nooney:

Adirondack Environmental Services, Inc received 98 samples on 2/7/2020 for the analyses presented in the following report.

Please see case narrative for specifics on analysis.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,

Tara Daniels
Laboratory Director

ELAP#: 10709

Adirondack Environmental Services, Inc**CASE NARRATIVE**

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Lab Order: 200207028

Date: 20-Feb-20

The sampling was performed in accordance with the AES field sampling procedures and/or the client specified sampling procedures. Sample containers were supplied by Adirondack Environmental Services.

Definitions - RL: Reporting Limit DF: Dilution factor

Qualifiers:	ND : Not Detected at reporting limit	C: CCV below acceptable Limits
	J: Analyte detected below quantitation limit	C+: CCV above acceptable Limits
	B: Analyte detected in Blank	S: LCS Spike recovery is below acceptable limits
	X : Exceeds maximum contamination limit	S+: LCS Spike recovery is above acceptable limits
	H: Hold time exceeded	Z: Duplication outside acceptable limits
	N: Matrix Spike below acceptable limits	T : Tentatively Identified Compound-Estimated
	N+: Matrix Spike is above acceptable limits	E :Above quantitation range-Estimated

Note : All Results are reported as wet weight unless noted

The results relate only to the items tested. Information supplied by the client is assumed to be correct.

Adirondack Environmental Services, Inc

Date: 20-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Pine Bush Elementary

LabWork Order: 200207028
PO#: 197320

Lab SampleID: 200207028-001**Collection Date:** 2/7/2020**Client Sample ID:** PBE-01**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	3.5	1.0		µg/L	1	2/13/2020 4:35:55 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 200207028-002**Collection Date:** 2/7/2020**Client Sample ID:** PBE-02**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	16.2	1.0	X	µg/L	1	2/13/2020 4:47:08 PM
------	------	-----	---	------	---	----------------------

Lab SampleID: 200207028-003**Collection Date:** 2/7/2020**Client Sample ID:** PBE-03**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	1.9	1.0		µg/L	1	2/13/2020 4:50:53 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 200207028-004**Collection Date:** 2/7/2020**Client Sample ID:** PBE-04**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 4:54:38 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200207028-005**Collection Date:** 2/7/2020**Client Sample ID:** PBE-05**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	3.3	1.0		µg/L	1	2/13/2020 4:58:23 PM
------	-----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 20-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Pine Bush Elementary

LabWork Order: 200207028
PO#: 197320

Lab SampleID: 200207028-006 **Collection Date:** 2/7/2020
Client Sample ID: PBE-06 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/7/2020)						
Lead	ND	1.0		µg/L	1	2/13/2020 5:02:09 PM

Lab SampleID: 200207028-007 **Collection Date:** 2/7/2020
Client Sample ID: PBE-07 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/7/2020)						
Lead	ND	1.0		µg/L	1	2/13/2020 5:13:22 PM

Lab SampleID: 200207028-008 **Collection Date:** 2/7/2020
Client Sample ID: PBE-08 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/7/2020)						
Lead	1.3	1.0		µg/L	1	2/13/2020 5:17:09 PM

Lab SampleID: 200207028-009 **Collection Date:** 2/7/2020
Client Sample ID: PBE-09 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/7/2020)						
Lead	ND	1.0		µg/L	1	2/13/2020 5:20:55 PM

Lab SampleID: 200207028-010 **Collection Date:** 2/7/2020
Client Sample ID: PBE-10 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/7/2020)						
Lead	ND	1.0		µg/L	1	2/13/2020 5:24:38 PM

Adirondack Environmental Services, Inc

Date: 20-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Pine Bush Elementary

LabWork Order: 200207028
PO#: 197320

Lab SampleID: 200207028-011**Collection Date:** 2/7/2020**Client Sample ID:** PBE-11**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 5:28:21 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200207028-012**Collection Date:** 2/7/2020**Client Sample ID:** PBE-12**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 5:39:31 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200207028-013**Collection Date:** 2/7/2020**Client Sample ID:** PBE-13**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	3.2	1.0		µg/L	1	2/13/2020 5:43:15 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 200207028-014**Collection Date:** 2/7/2020**Client Sample ID:** PBE-14**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 5:46:59 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200207028-015**Collection Date:** 2/7/2020**Client Sample ID:** PBE-15**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 5:58:11 PM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 20-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Pine Bush Elementary

LabWork Order: 200207028
PO#: 197320

Lab SampleID: 200207028-016**Collection Date:** 2/7/2020**Client Sample ID:** PBE-16**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 6:01:56 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200207028-017**Collection Date:** 2/7/2020**Client Sample ID:** PBE-17**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 6:05:41 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200207028-018**Collection Date:** 2/7/2020**Client Sample ID:** PBE-18**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	1.7	1.0		µg/L	1	2/13/2020 6:09:26 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 200207028-019**Collection Date:** 2/7/2020**Client Sample ID:** PBE-19**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 6:13:11 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200207028-020**Collection Date:** 2/7/2020**Client Sample ID:** PBE-20**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 6:16:54 PM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 20-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Pine Bush Elementary

LabWork Order: 200207028
PO#: 197320

Lab SampleID: 200207028-021**Collection Date:** 2/7/2020**Client Sample ID:** PBE-21**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 6:28:03 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200207028-022**Collection Date:** 2/7/2020**Client Sample ID:** PBE-22**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 6:46:42 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200207028-023**Collection Date:** 2/7/2020**Client Sample ID:** PBE-23**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 6:50:26 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200207028-024**Collection Date:** 2/7/2020**Client Sample ID:** PBE-24**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 6:54:11 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200207028-025**Collection Date:** 2/7/2020**Client Sample ID:** PBE-25**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 6:57:56 PM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 20-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Pine Bush Elementary

LabWork Order: 200207028
PO#: 197320

Lab SampleID: 200207028-026**Collection Date:** 2/7/2020**Client Sample ID:** PBE-25A**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 7:01:42 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200207028-027**Collection Date:** 2/7/2020**Client Sample ID:** PBE-26**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 7:05:27 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200207028-028**Collection Date:** 2/7/2020**Client Sample ID:** PBE-28**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 7:09:10 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200207028-029**Collection Date:** 2/7/2020**Client Sample ID:** PBE-29**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 7:12:53 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200207028-030**Collection Date:** 2/7/2020**Client Sample ID:** PBE-30**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	9.2	1.0		µg/L	1	2/13/2020 7:16:36 PM
------	-----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 20-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Pine Bush Elementary

LabWork Order: 200207028
PO#: 197320

Lab SampleID: 200207028-031**Collection Date:** 2/7/2020**Client Sample ID:** PBE-31**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 7:27:47 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200207028-032**Collection Date:** 2/7/2020**Client Sample ID:** PBE-32**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 7:38:58 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200207028-033**Collection Date:** 2/7/2020**Client Sample ID:** PBE-33**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 7:42:42 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200207028-034**Collection Date:** 2/7/2020**Client Sample ID:** PBE-34**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 7:46:27 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200207028-035**Collection Date:** 2/7/2020**Client Sample ID:** PBE-35**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 7:50:11 PM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 20-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Pine Bush Elementary

LabWork Order: 200207028
PO#: 197320

Lab SampleID: 200207028-036**Collection Date:** 2/7/2020**Client Sample ID:** PBE-36**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 7:53:57 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200207028-037**Collection Date:** 2/7/2020**Client Sample ID:** PBE-36A**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 7:57:42 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200207028-038**Collection Date:** 2/7/2020**Client Sample ID:** PBE-37**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 8:01:26 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200207028-039**Collection Date:** 2/7/2020**Client Sample ID:** PBE-38**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 8:05:09 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200207028-040**Collection Date:** 2/7/2020**Client Sample ID:** PBE-39**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 8:16:20 PM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 20-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Pine Bush Elementary

LabWork Order: 200207028
PO#: 197320

Lab SampleID: 200207028-041**Collection Date:** 2/7/2020**Client Sample ID:** PBE-40**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	1.2	1.0		µg/L	1	2/13/2020 8:27:31 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 200207028-042**Collection Date:** 2/7/2020**Client Sample ID:** PBE-41**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 8:38:44 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200207028-043**Collection Date:** 2/7/2020**Client Sample ID:** PBE-42**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	1.0	1.0		µg/L	1	2/13/2020 8:42:29 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 200207028-044**Collection Date:** 2/7/2020**Client Sample ID:** PBE-43**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 8:46:14 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200207028-045**Collection Date:** 2/7/2020**Client Sample ID:** PBE-45**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	1.7	1.0		µg/L	1	2/13/2020 8:50:00 PM
------	-----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 20-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Pine Bush Elementary

LabWork Order: 200207028
PO#: 197320

Lab SampleID: 200207028-046**Collection Date:** 2/7/2020**Client Sample ID:** PBE-46**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 9:01:11 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200207028-047**Collection Date:** 2/7/2020**Client Sample ID:** PBE-47**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 9:04:55 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200207028-048**Collection Date:** 2/7/2020**Client Sample ID:** PBE-48**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 9:08:39 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200207028-049**Collection Date:** 2/7/2020**Client Sample ID:** PBE-49**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	1.8	1.0		µg/L	1	2/13/2020 9:12:23 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 200207028-050**Collection Date:** 2/7/2020**Client Sample ID:** PBE-50**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 9:16:07 PM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 20-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Pine Bush Elementary

LabWork Order: 200207028
PO#: 197320

Lab SampleID: 200207028-051 **Collection Date:** 2/7/2020
Client Sample ID: PBE-51 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: **SM**
(Prep: - 2/7/2020)

Lead	7.9	1.0		µg/L	1	2/13/2020 9:19:51 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 200207028-052 **Collection Date:** 2/7/2020
Client Sample ID: PBE-52 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: **SM**
(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 9:31:04 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200207028-053 **Collection Date:** 2/7/2020
Client Sample ID: PBE-52A **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: **SM**
(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 9:34:49 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200207028-054 **Collection Date:** 2/7/2020
Client Sample ID: PBE-53 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: **SM**
(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 9:46:02 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200207028-055 **Collection Date:** 2/7/2020
Client Sample ID: PBE-54 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: **SM**
(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 9:49:48 PM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 20-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Pine Bush Elementary

LabWork Order: 200207028
PO#: 197320

Lab SampleID: 200207028-056**Collection Date:** 2/7/2020**Client Sample ID:** PBE-55**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 9:53:32 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200207028-057**Collection Date:** 2/7/2020**Client Sample ID:** PBE-56**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 9:57:17 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200207028-058**Collection Date:** 2/7/2020**Client Sample ID:** PBE-57**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 10:01:01 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 200207028-059**Collection Date:** 2/7/2020**Client Sample ID:** PBE-58**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 10:04:45 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 200207028-060**Collection Date:** 2/7/2020**Client Sample ID:** PBE-59**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 10:08:30 PM
------	----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 20-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Pine Bush Elementary

LabWork Order: 200207028
PO#: 197320

Lab SampleID: 200207028-061**Collection Date:** 2/7/2020**Client Sample ID:** PBE-60**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	2.2	1.0		µg/L	1	2/13/2020 10:19:43 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 200207028-062**Collection Date:** 2/7/2020**Client Sample ID:** PBE-61**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 10:38:26 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 200207028-063**Collection Date:** 2/7/2020**Client Sample ID:** PBE-62**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 10:42:11 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 200207028-064**Collection Date:** 2/7/2020**Client Sample ID:** PBE-62A**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 10:45:56 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 200207028-065**Collection Date:** 2/7/2020**Client Sample ID:** PBE-63**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	1.4	1.0		µg/L	1	2/13/2020 10:49:40 PM
------	-----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 20-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Pine Bush Elementary

LabWork Order: 200207028
PO#: 197320

Lab SampleID: 200207028-066**Collection Date:** 2/7/2020**Client Sample ID:** PBE-64**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 10:53:25 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 200207028-067**Collection Date:** 2/7/2020**Client Sample ID:** PBE-65**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 10:57:09 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 200207028-068**Collection Date:** 2/7/2020**Client Sample ID:** PBE-66**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 11:00:54 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 200207028-069**Collection Date:** 2/7/2020**Client Sample ID:** PBE-67**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 11:04:38 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 200207028-070**Collection Date:** 2/7/2020**Client Sample ID:** PBE-68**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 11:15:50 PM
------	----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 20-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Pine Bush Elementary

LabWork Order: 200207028
PO#: 197320

Lab SampleID: 200207028-071**Collection Date:** 2/7/2020**Client Sample ID:** PBE-69**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 11:19:35 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 200207028-072**Collection Date:** 2/7/2020**Client Sample ID:** PBE-70**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 11:30:50 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 200207028-073**Collection Date:** 2/7/2020**Client Sample ID:** PBE-71**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 11:34:36 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 200207028-074**Collection Date:** 2/7/2020**Client Sample ID:** PBE-72**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 11:38:21 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 200207028-075**Collection Date:** 2/7/2020**Client Sample ID:** PBE-73**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 11:42:05 PM
------	----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 20-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Pine Bush Elementary

LabWork Order: 200207028
PO#: 197320

Lab SampleID: 200207028-076**Collection Date:** 2/7/2020**Client Sample ID:** PBE-74**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 11:45:50 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 200207028-077**Collection Date:** 2/7/2020**Client Sample ID:** PBE-75**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 11:49:35 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 200207028-078**Collection Date:** 2/7/2020**Client Sample ID:** PBE-78**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 11:53:20 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 200207028-079**Collection Date:** 2/7/2020**Client Sample ID:** PBE-79**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	2.5	1.0		µg/L	1	2/14/2020 12:04:33 AM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 200207028-080**Collection Date:** 2/7/2020**Client Sample ID:** PBE-80**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	52.4	1.0	X	µg/L	1	2/14/2020 12:08:17 AM
------	------	-----	---	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 20-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Pine Bush Elementary

LabWork Order: 200207028
PO#: 197320

Lab SampleID: 200207028-081 **Collection Date:** 2/7/2020
Client Sample ID: PBE-81 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: **SM**
(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/14/2020 12:19:32 AM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 200207028-082 **Collection Date:** 2/7/2020
Client Sample ID: PBE-82 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: **SM**
(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/14/2020 12:30:48 AM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 200207028-083 **Collection Date:** 2/7/2020
Client Sample ID: PBE-83 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: **SM**
(Prep: - 2/7/2020)

Lead	3.5	1.0		µg/L	1	2/14/2020 12:34:33 AM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 200207028-084 **Collection Date:** 2/7/2020
Client Sample ID: PBE-84 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: **SM**
(Prep: - 2/7/2020)

Lead	1.6	1.0		µg/L	1	2/14/2020 12:38:18 AM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 200207028-085 **Collection Date:** 2/7/2020
Client Sample ID: PBE-85 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: **SM**
(Prep: - 2/7/2020)

Lead	1.3	1.0		µg/L	1	2/14/2020 12:42:03 AM
------	-----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 20-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Pine Bush Elementary

LabWork Order: 200207028
PO#: 197320

Lab SampleID: 200207028-086**Collection Date:** 2/7/2020**Client Sample ID:** PBE-86**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/14/2020 12:45:48 AM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 200207028-087**Collection Date:** 2/7/2020**Client Sample ID:** PBE-87**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	9.9	1.0		µg/L	1	2/14/2020 12:49:34 AM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 200207028-088**Collection Date:** 2/7/2020**Client Sample ID:** PBE-88**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	2.5	1.0		µg/L	1	2/14/2020 12:53:19 AM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 200207028-089**Collection Date:** 2/7/2020**Client Sample ID:** PBE-89**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	2.4	1.0		µg/L	1	2/14/2020 12:57:04 AM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 200207028-090**Collection Date:** 2/7/2020**Client Sample ID:** PBE-90**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	1.3	1.0		µg/L	1	2/14/2020 1:00:49 AM
------	-----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 20-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Pine Bush Elementary

LabWork Order: 200207028
PO#: 197320

Lab SampleID: 200207028-091**Collection Date:** 2/7/2020**Client Sample ID:** PBE-91**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/14/2020 1:12:02 AM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200207028-092**Collection Date:** 2/7/2020**Client Sample ID:** PBE-92**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/14/2020 1:23:19 AM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200207028-093**Collection Date:** 2/7/2020**Client Sample ID:** PBE-93**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/14/2020 1:27:04 AM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200207028-094**Collection Date:** 2/7/2020**Client Sample ID:** PBE-94**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/14/2020 1:30:50 AM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200207028-095**Collection Date:** 2/7/2020**Client Sample ID:** PBE-94A**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/14/2020 1:34:36 AM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 20-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Pine Bush Elementary

LabWork Order: 200207028
PO#: 197320

Lab SampleID: 200207028-096**Collection Date:** 2/7/2020**Client Sample ID:** PBE-95**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	4.4	1.0		µg/L	1	2/14/2020 1:38:21 AM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 200207028-097**Collection Date:** 2/7/2020**Client Sample ID:** PBE-96**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	ND	1.0		µg/L	1	2/14/2020 1:42:07 AM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200207028-098**Collection Date:** 2/7/2020**Client Sample ID:** PBE-97**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/7/2020)

Lead	2.0	1.0		µg/L	1	2/14/2020 1:45:53 AM
------	-----	-----	--	------	---	----------------------



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#:

200207028

COC Reference:

1378

A full service analytical research laboratory offering solutions to environmental concerns

AES Sample Number		Client Sample Identification & Location		Date	Time	Sample Type			# of Cont's	Preservative	Analysis
						Matrix	C	G			
001	PBE- 01	2/7/20	0615	PW		X			1	0	Lead
002	PBE- 02	2/7/20	0617	PW		X			1	0	Lead
003	PBE- 03	2/7/20	0602	PW		X			1	0	Lead
004	PBE- 04	2/7/20	0602	PW		X			1	0	Lead
005	PBE- 05	2/7/20	0602	PW		X			1	0	Lead
006	PBE- 06	2/7/20	0617	PW		X			1	0	Lead
007	PBE- 07	2/7/20	0617	PW		X			1	0	Lead
008	PBE- 08	2/7/20	0618	PW		X			1	0	Lead
009	PBE- 09	2/7/20	0458	PW		X			1	0	Lead
010	PBE- 10	2/7/20	0458	PW		X			1	0	Lead
011	PBE- 11	2/7/20	0458	PW		X			1	0	Lead
012	PBE- 12	2/7/20	0459	PW		X			1	0	Lead
013	PBE- 13	2/7/20	0459	PW		X			1	0	Lead
014	PBE- 14	2/7/20	0459	PW		X			1	0	Lead
015	PBE- 15	2/7/20	0500	PW		X			1	0	Lead
016	PBE- 16	2/7/20	0500	PW		X			1	0	Lead

Shipment Arrived Via: <u>Client</u> <u>AES</u> Other: _____		Special Instructions/Remarks:	
Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day <u>Standard</u>			
NOTE: Samples received after 3:30pm are considered next business day.			

Relinquished by: (Signature)		Received by: (Signature)		Date	Time
Relinquished by: (Signature)		Received for Laboratory by:		Date	Time
				2/7/20	1143Am

Sample Temperature <u>Ambient</u>	Properly Preserved: <u>Y</u> / N	Received Within Holding Times: <u>Y</u> / N
Notes: Ice preservation not required	0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 3=HCl pH<2 4=Na ₂ S ₂ O ₃	5=NH ₄ Cl 6=As 7=F 8=Z 9=I 10=
Bottles AES: <u>Y</u> / N		



200207028



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#:

200207028

COC Reference:

1378

A full service analytical research laboratory offering solutions to environmental concerns

AES Sample Number		Client Sample Identification & Location		Date	Time	Sample Type			# of Cont's	Preservative	Analysis
						Matrix	C	G			
017		PBE- 17		2/7/20	0500	PW		X	1	0	Lead
018		PBE- 18			0501	PW		X	1	0	Lead
019		PBE- 19			0502	PW		X	1	0	Lead
020		PBE- 20			0502	PW		X	1	0	Lead
021		PBE- 21			0503	PW		X	1	0	Lead
022		PBE- 22			0504	PW		X	1	0	Lead
023		PBE- 23			0459	PW		X	1	0	Lead
024		PBE- 24			0509	PW		X	1	0	Lead
025		PBE- 25			0509	PW		X	1	0	Lead
026		PBE- 25A			0509	PW		X	1	0	Lead
027		PBE- 26			0510	PW		X	1	0	Lead
028		PBE- 28			0510	PW		X	1	0	Lead
029		PBE- 29			0511	PW		X	1	0	Lead
030		PBE- 30			0512	PW		X	1	0	Lead
031		PBE- 31			0513	PW		X	1	0	Lead
032		PBE- 32			0513	PW		X	1	0	Lead

Shipment Arrived Via: <u>Client</u> <u>AES</u> Other:		Special Instructions/Remarks:	
FedEx UPS			
Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day <u>Standard</u>			
NOTE: Samples received after 3:30pm are considered next business day.		PLEASE FILL ALL PINK SHADED AREAS	
Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received for Laboratory by:	Date	Time
Sample Temperature: <u>Ambient</u>		Properly Preserved: <u>Y</u> / <u>N</u>	
Notes: Ice preservation not required		Received Within Holding Times: <u>Y</u> / <u>N</u>	
Bottles AES: <u>Y</u> / <u>N</u>		Notes:	



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#:

000207028

COC Reference:

1378

A full service analytical research laboratory offering solutions to environmental concerns

AES Sample Number		Client Sample Identification & Location		Date	Time	Sample Type			# of Cont's	Preservative	Analysis
						Matrix	C	G			
033	PBE- 33	2/7/20	0513	PW		X			1	0	Lead
034	PBE- 34		0514	PW		X			1	0	Lead
035	PBE- 35		0514	PW		X			1	0	Lead
036	PBE- 36		0515	PW		X			1	0	Lead
037	PBE- 36A		0518	PW		X			1	0	Lead
038	PBE- 37		0519	PW		X			1	0	Lead
039	PBE- 38		0519	PW		X			1	0	Lead
040	PBE- 39		0520	PW		X			1	0	Lead
041	PBE- 40		0520	PW		X			1	0	Lead
042	PBE- 41		0520	PW		X			1	0	Lead
043	PBE- 42		0530	PW		X			1	0	Lead
044	PBE- 43		0530	PW		X			1	0	Lead
045	PBE- 45		0530	PW		X			1	0	Lead
046	PBE- 46		0532	PW		X			1	0	Lead
047	PBE- 47		0530	PW		X			1	0	Lead
	PBE- 47A		0530	PW		X			1	0	Lead

Shipment Arrived Via: <u>Client</u> <u>AES</u> Other:		Special Instructions/Remarks:	
Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day <u>Standard</u>			
NOTE: Samples received after 3:30pm are considered next business day.			

Relinquished by: (Signature)		Received by: (Signature)		Date	Time
		Received for Laboratory by:		Date	Time
				2/7/20	1143AM

Sample Temperature: <u>Ambient</u>	Properly Preserved: <u>Y</u> / N	Received Within Holding Times: <u>Y</u> / N
Notes: Ice preservation not required	0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 3=HCl pH<2 4=Na ₂ S ₂ O ₃	Notes:
Bottles AES: <u>Y</u> / N	5=NH ₄ Cl 6=Ascorbic Acid 7=FAS 8=ZnAc/NaOH pH>9 9=NaOH pH>10 10=Other	



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#:

200207028

COC Reference:

1378

A full service analytical research laboratory offering solutions to environmental concerns

AES Sample Number		Client Sample Identification & Location		Date	Time	Sample Type			# of Cont's	Preservative	Analysis
						Matrix	C	G			
048	PBE- 48			2/7/20	0532	PW		X	1	0	Lead
049	PBE- 49				0532	PW		X	1	0	Lead
050	PBE- 50				0541	PW		X	1	0	Lead
051	PBE- 51				0542	PW		X	1	0	Lead
052	PBE- 52				0544	PW		X	1	0	Lead
053	PBE- 52A				0544	PW		X	1	0	Lead
054	PBE- 53				0545	PW		X	1	0	Lead
055	PBE- 54				0545	PW		X	1	0	Lead
056	PBE- 55				0545	PW		X	1	0	Lead
057	PBE- 56				0544	PW		X	1	0	Lead
058	PBE- 57				0545	PW		X	1	0	Lead
059	PBE- 58				0545	PW		X	1	0	Lead
060	PBE- 59				0545	PW		X	1	0	Lead
061	PBE- 60				0547	PW		X	1	0	Lead
062	PBE- 61				0547	PW		X	1	0	Lead
063	PBE- 62				0547	PW		X	1	0	Lead

Shipment Arrived Via: FedEx UPS Client <u>AES</u> Other:		Special Instructions/Remarks:	
Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day <u>Standard</u>			
NOTE: Samples received after 3:30pm are considered next business day.			

Relinquished by: (Signature)		Received by: (Signature)		Date	Time
Relinquished by: (Signature)		Received for Laboratory by:		Date	Time
				2/7/20	11:43AM

Sample Temperature <u>Ambient</u> Notes: Ice preservation not required	Properly Preserved: <u>Y</u> / N 0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 3=HCl pH<2 4=Na ₂ S ₂ O ₃ 5=NH ₄ Cl 6=Ascorbic Acid 7=FAS 8=ZnAc/NaOH pH>9 9=NaOH pH>10 10=Other	Received Within Holding Times: <u>Y</u> / N Notes:
Bottles AES: <u>Y</u> / N		



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#:

200207028

COC Reference:

1378

A full service analytical research laboratory offering solutions to environmental concerns

Guilderland Central School District		Address:							
Tim Murphy, Clifford Nooney		Project Name (Location): Pine Bush Elementary				Samplers Name: <i>Michael O'Neil</i>			
Client Phone #:		Client PO #:				Samplers Signature: <i>[Signature]</i>			
Client Email:									
AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis
				Matrix	C	G			
064	PBE- 62A	2/7/20	0547	PW		X	1	0	Lead
065	PBE- 63		0549	PW		X	1	0	Lead
066	PBE- 64		0550	PW		X	1	0	Lead
067	PBE- 65		0550	PW		X	1	0	Lead
068	PBE- 66		0550	PW		X	1	0	Lead
069	PBE- 67		0551	PW		X	1	0	Lead
070	PBE- 68		0551	PW		X	1	0	Lead
071	PBE- 69		0551	PW		X	1	0	Lead
072	PBE- 70		0551	PW		X	1	0	Lead
073	PBE- 71		0552	PW		X	1	0	Lead
074	PBE- 72		0552	PW		X	1	0	Lead
075	PBE- 73		0552	PW		X	1	0	Lead
076	PBE- 74		0552	PW		X	1	0	Lead
077	PBE- 75		0552	PW		X	1	0	Lead
078	PBE- 78		0555	PW		X	1	0	Lead
079	PBE- 73		0555	PW		X	1	0	Lead
Shipment Arrived Via: FedEx UPS Client <u>AES</u> Other:				Special Instructions/Remarks:					
Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day <u>Standard</u>				PLEASE FILL ALL PINK SHADED AREAS					
Relinquished by: (Signature)				Received by: (Signature)				Date	Time
Relinquished by: (Signature)				Received by: (Signature)				Date	Time
Relinquished by: (Signature)				Received for Laboratory by:				Date	Time
Sample Temperature <u>Ambient</u>				Properly Preserved: <u>Y</u> / N				Received Within Holding Times: <u>Y</u> / N	
Notes: Ice preservation not required				0=None 5=NH ₄ Cl 1=H ₂ SO ₄ pH<2 6=Ascorbic Acid 2=HNO ₃ pH<2 7=FAS 3=HCl pH<2 8=ZnAc/NaOH pH>9 4=Na ₂ S ₂ O ₃ 9=NaOH pH>10 10=Other _____				Notes:	
Bottles AES: <u>Y</u> / N									



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#:

200207028

COC Reference:

1378

A full service analytical research laboratory offering solutions to environmental concerns

AES Sample Number		Client Sample Identification & Location		Date	Time	Sample Type			# of Cont's	Preservative	Analysis
						Matrix	C	G			
080	PBE- 80			2/7/20	0555	PW		X	1	0	Lead
081	PBE- 81				0556	PW		X	1	0	Lead
082	PBE- 82				0556	PW		X	1	0	Lead
083	PBE- 83				0557	PW		X	1	0	Lead
084	PBE- 84				0557	PW		X	1	0	Lead
085	PBE- 85				0610	PW		X	1	0	Lead
086	PBE- 86				0610	PW		X	1	0	Lead
087	PBE- 87				0600	PW		X	1	0	Lead
088	PBE- 88				0611	PW		X	1	0	Lead
089	PBE- 89				0612	PW		X	1	0	Lead
090	PBE- 90				0530	PW		X	1	0	Lead
091	PBE- 91				0532	PW		X	1	0	Lead
092	PBE- 92				0530	PW		X	1	0	Lead
093	PBE- 93				0530	PW		X	1	0	Lead
094	PBE- 94				0531	PW		X	1	0	Lead
095	PBE- 94A				0531	PW		X	1	0	Lead

Shipment Arrived Via: FedEx UPS Client AES Other:		Special Instructions/Remarks:	
Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day <u>Standard</u>			
NOTE: Samples received after 3:30pm are considered next business day.			

Relinquished by: (Signature)		Received by: (Signature)		Date	Time
Relinquished by: (Signature)		Received for Laboratory by:		Date	Time
				2/7/20	11:43A

Sample Temperature <u>Ambient</u> Notes: Ice preservation not required	Properly Preserved: Y / N 0=None 5=NH ₄ Cl 1=H ₂ SO ₄ pH<2 6=Ascorbic Acid 2=HNO ₃ pH<2 7=FAS 3=HCl pH<2 8=ZnAc/NaOH pH>9 4=Na ₂ S ₂ O ₃ 9=NaOH pH>10 10=Other _____	Received Within Holding Times: Y / N Notes:
Bottles AES: Y / N		



CHAIN OF CUSTODY RECORD

AES Work Order#:

COC Reference:

1378

A full service analytical research laboratory offering solutions to environmental concerns

Guilderland Central School District			Address:			
Tim Murphy, Clifford Nooney			Project Name (Location): Pine Bush Elementary		Samplers Name: <i>Michael Wil...</i>	
Client Phone #:			Client PO #:		Samplers Signature: <i>[Signature]</i>	
Client Email:						
AES Sample Number	Client Sample Identification & Location	Date	Time	Sample Type Matrix C G	# of Cont's Preservative	Analysis
096	PBE- 95	2/7/20	0530	PW	X	1 0 Lead
097	PBE- 96	↓	0530	PW	X	1 0 Lead
098	PBE- 97	↓	0620	PW	X	1 0 Lead
	PBE-			PW	X	1 0 Lead
	PBE-			PW	X	1 0 Lead
	PBE-			PW	X	1 0 Lead
	PBE-			PW	X	1 0 Lead
	PBE-			PW	X	1 0 Lead
	PBE-			PW	X	1 0 Lead
	PBE-			PW	X	1 0 Lead
	PBE-			PW	X	1 0 Lead
	PBE-			PW	X	1 0 Lead
	PBE-			PW	X	1 0 Lead
	PBE-			PW	X	1 0 Lead
	PBE-			PW	X	1 0 Lead
	PBE-			PW	X	1 0 Lead
	PBE-			PW	X	1 0 Lead
	PBE-			PW	X	1 0 Lead
Shipment Arrived Via: FedEx UPS Client <u>AES</u> Other:			Special Instructions/Remarks:			
Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day <u>Standard</u>						
NOTE: Samples received after 3:30pm are considered next business day.			PLEASE FILL ALL PINK SHADED AREAS			
Relinquished by: (Signature)		Received by: (Signature)		Date	Time	
Relinquished by: (Signature)		Received by: (Signature)		Date	Time	
Relinquished by: (Signature)		Received for Laboratory by:		Date	Time	
Sample Temperature <u>Ambient</u>		Properly Preserved: Y / N 0=None 5=NH ₄ Cl 1=H ₂ SO ₄ pH<2 6=Ascorbic Acid 2=HNO ₃ pH<2 7=FAS 3=HCl pH<2 8=ZnAc/NaOH pH>9 4=Na ₂ S ₂ O ₃ 9=NaOH pH>10 10=Other		Received Within Holding Times: Y / N		
Notes: Ice preservation not required				Notes:		
Bottles AES: Y / N						



Experience is the solution

314 North Pearl Street • Albany, New York 12207 • (518) 434-4546 • Fax (518) 434-0891

TERMS, CONDITIONS & LIMITATIONS

All service rendered by the **Adirondack Environmental Services, Inc.** are undertaken and all rates are based upon the following terms:

- (a) Neither **Adirondack Environmental Services, Inc.**, nor any of its employees, agents or sub-contractors shall be liable for any loss or damage arising out of **Adirondack Environmental Services, Inc.**'s performance or nonperformance, whether by way of negligence or breach of contract, or otherwise, in any amount greater than twice the amount billed to the customer for the work leading to the claim of the customer. Said remedy shall be the sole and exclusive remedy against **Adirondack Environmental Services, Inc.** arising out of its work.
- (b) All claims made must be in writing within forty-five (45) days after delivery of the **Adirondack Environmental Services, Inc.** report regarding said work or such claim shall be deemed or irrevocably waived.
- (c) **Adirondack Environmental Services, Inc.** reports are submitted in writing and are for our customers only. Our customers are considered to be only those entities being billed for our services. Acquisition of an **Adirondack Environmental Services, Inc.** report by other than our customer does not constitute a representation of **Adirondack Environmental Services, Inc.** as to the accuracy of the contents thereof.
- (d) In no event shall **Adirondack Environmental Services, Inc.**, its employees, agents or sub-contractors be responsible for consequential or special damages of any kind or in any amount.
- (e) No deviation from the terms set forth herein shall bind **Adirondack Environmental Services, Inc.** unless in writing and signed by a Director of **Adirondack Environmental Services, Inc.**
- (f) Results pertain only to items analyzed. Information supplied by client is assumed to be correct. This information may be used on reports and in calculations and **Adirondack Environmental Services, Inc.** is not responsible for the accuracy of this information.
- (g) Payments by Credit Card/Purchase Cards are subject to a 3% additional charge.