



Experience is the solution

314 North Pearl Street ♦ Albany, New York 12207
(800) 848-4983 ♦ (518) 434-4546 ♦ Fax (518) 434-0891

February 19, 2020

Clifford Nooney
Guilderland CSD
PO Box 381
Guilderland Center, NY 12085
TEL: (518) 456-6200

Work Order No: 200206036
PO#: 197320

RE: 2020 Lead Sampling and Analysis
Westmere Elementary

Dear Clifford Nooney:

Adirondack Environmental Services, Inc received 101 samples on 2/6/2020 for the analyses presented in the following report.

Please see case narrative for specifics on analysis.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,

Tara Daniels
Laboratory Director

ELAP#: 10709

Adirondack Environmental Services, Inc

CASE NARRATIVE

CLIENT: Guilderland CSD

Date: 19-Feb-20

Project: 2020 Lead Sampling and Analysis

Lab Order: 200206036

Sample containers were supplied by Adirondack Environmental Services.

Definitions - RL: Reporting Limit DF: Dilution factor

Qualifiers:	ND : Not Detected at reporting limit	C: CCV below acceptable Limits
	J: Analyte detected below quantitation limit	C+: CCV above acceptable Limits
	B: Analyte detected in Blank	S: LCS Spike recovery is below acceptable limits
	X : Exceeds maximum contamination limit	S+: LCS Spike recovery is above acceptable limits
	H: Hold time exceeded	Z: Duplication outside acceptable limits
	N: Matrix Spike below acceptable limits	T : Tentatively Identified Compound-Estimated
	N+: Matrix Spike is above acceptable limits	E :Above quantitation range-Estimated

Note : All Results are reported as wet weight unless noted

The results relate only to the items tested. Information supplied by the client is assumed to be correct.

Adirondack Environmental Services, Inc

Date: 19-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Westmere Elementary

LabWork Order: 200206036
PO#: 197320

Lab SampleID: 200206036-001**Collection Date:** 2/6/2020**Client Sample ID:** WES-01**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/6/2020)

Lead	1.0	1.0		µg/L	1	2/12/2020 5:16:35 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 200206036-002**Collection Date:** 2/6/2020**Client Sample ID:** WES-02**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/6/2020)

Lead	ND	1.0		µg/L	1	2/12/2020 5:27:48 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200206036-003**Collection Date:** 2/6/2020**Client Sample ID:** WES-03**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/6/2020)

Lead	ND	1.0		µg/L	1	2/12/2020 5:31:33 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200206036-004**Collection Date:** 2/6/2020**Client Sample ID:** WES-03A**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/6/2020)

Lead	1.1	1.0		µg/L	1	2/12/2020 5:35:18 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 200206036-005**Collection Date:** 2/6/2020**Client Sample ID:** WES-04**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/6/2020)

Lead	ND	1.0		µg/L	1	2/12/2020 5:39:03 PM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 19-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Westmere Elementary

LabWork Order: 200206036
PO#: 197320

Lab SampleID: 200206036-006**Collection Date:** 2/6/2020**Client Sample ID:** WES-05**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/6/2020)

Lead	3.6	1.0		µg/L	1	2/12/2020 5:42:49 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 200206036-007**Collection Date:** 2/6/2020**Client Sample ID:** WES-06**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/6/2020)

Lead	ND	1.0		µg/L	1	2/12/2020 5:54:02 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200206036-008**Collection Date:** 2/6/2020**Client Sample ID:** WES-07**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/6/2020)

Lead	2.9	1.0		µg/L	1	2/12/2020 5:57:49 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 200206036-009**Collection Date:** 2/6/2020**Client Sample ID:** WES-08**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/6/2020)

Lead	1.6	1.0		µg/L	1	2/12/2020 6:01:35 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 200206036-010**Collection Date:** 2/6/2020**Client Sample ID:** WES-10**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/6/2020)

Lead	4.2	1.0		µg/L	1	2/12/2020 6:05:17 PM
------	-----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 19-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Westmere Elementary

LabWork Order: 200206036
PO#: 197320

Lab SampleID: 200206036-011**Collection Date:** 2/6/2020**Client Sample ID:** WES-11**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/6/2020)

Lead	ND	1.0		µg/L	1	2/12/2020 6:09:00 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200206036-012**Collection Date:** 2/6/2020**Client Sample ID:** WES-12**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/6/2020)

Lead	ND	1.0		µg/L	1	2/12/2020 6:20:10 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200206036-013**Collection Date:** 2/6/2020**Client Sample ID:** WES-13**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/6/2020)

Lead	1.0	1.0		µg/L	1	2/12/2020 6:23:54 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 200206036-014**Collection Date:** 2/6/2020**Client Sample ID:** WES-14**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/6/2020)

Lead	ND	1.0		µg/L	1	2/12/2020 6:27:38 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200206036-015**Collection Date:** 2/6/2020**Client Sample ID:** WES-15**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/6/2020)

Lead	ND	1.0		µg/L	1	2/12/2020 6:38:50 PM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 19-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Westmere Elementary

LabWork Order: 200206036
PO#: 197320

Lab SampleID: 200206036-016 **Collection Date:** 2/6/2020
Client Sample ID: WES-16 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/6/2020)						
Lead	ND	1.0		µg/L	1	2/12/2020 6:42:34 PM

Lab SampleID: 200206036-017 **Collection Date:** 2/6/2020
Client Sample ID: WES-17 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/6/2020)						
Lead	ND	1.0		µg/L	1	2/12/2020 6:46:19 PM

Lab SampleID: 200206036-018 **Collection Date:** 2/6/2020
Client Sample ID: WES-18 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/6/2020)						
Lead	ND	1.0		µg/L	1	2/12/2020 6:50:04 PM

Lab SampleID: 200206036-019 **Collection Date:** 2/6/2020
Client Sample ID: WES-19 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/6/2020)						
Lead	ND	1.0		µg/L	1	2/12/2020 6:53:50 PM

Lab SampleID: 200206036-020 **Collection Date:** 2/6/2020
Client Sample ID: WES-20 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/6/2020)						
Lead	ND	1.0		µg/L	1	2/12/2020 6:57:33 PM

Adirondack Environmental Services, Inc

Date: 19-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Westmere Elementary

LabWork Order: 200206036
PO#: 197320

Lab SampleID: 200206036-021**Collection Date:** 2/6/2020**Client Sample ID:** WES-21**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/6/2020)

Lead	ND	1.0		µg/L	1	2/12/2020 7:08:41 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200206036-022**Collection Date:** 2/6/2020**Client Sample ID:** WES-22**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/6/2020)

Lead	2.5	1.0		µg/L	1	2/12/2020 7:27:20 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 200206036-023**Collection Date:** 2/6/2020**Client Sample ID:** WES-23**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/6/2020)

Lead	1.7	1.0		µg/L	1	2/12/2020 7:31:05 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 200206036-024**Collection Date:** 2/6/2020**Client Sample ID:** WES-24**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/6/2020)

Lead	ND	1.0		µg/L	1	2/12/2020 7:34:49 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200206036-025**Collection Date:** 2/6/2020**Client Sample ID:** WES-25**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/6/2020)

Lead	1.9	1.0		µg/L	1	2/12/2020 7:38:34 PM
------	-----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 19-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Westmere Elementary

LabWork Order: 200206036
PO#: 197320

Lab SampleID: 200206036-026**Collection Date:** 2/6/2020**Client Sample ID:** WES-26**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/6/2020)

Lead	2.7	1.0		µg/L	1	2/12/2020 7:42:19 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 200206036-027**Collection Date:** 2/6/2020**Client Sample ID:** WES-27**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/6/2020)

Lead	4.1	1.0		µg/L	1	2/12/2020 7:46:05 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 200206036-028**Collection Date:** 2/6/2020**Client Sample ID:** WES-28**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/6/2020)

Lead	ND	1.0		µg/L	1	2/12/2020 7:49:48 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200206036-029**Collection Date:** 2/6/2020**Client Sample ID:** WES-29**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/6/2020)

Lead	5.1	1.0		µg/L	1	2/12/2020 7:53:31 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 200206036-030**Collection Date:** 2/6/2020**Client Sample ID:** WES-30**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/6/2020)

Lead	8.8	1.0		µg/L	1	2/12/2020 7:57:14 PM
------	-----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 19-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Westmere Elementary

LabWork Order: 200206036
PO#: 197320

Lab SampleID: 200206036-031 **Collection Date:** 2/6/2020
Client Sample ID: WES-31 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/6/2020)						
Lead	2.9	1.0		µg/L	1	2/12/2020 8:08:24 PM

Lab SampleID: 200206036-032 **Collection Date:** 2/6/2020
Client Sample ID: WES-32 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/6/2020)						
Lead	3.3	1.0		µg/L	1	2/12/2020 8:19:36 PM

Lab SampleID: 200206036-033 **Collection Date:** 2/6/2020
Client Sample ID: WES-33 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/6/2020)						
Lead	ND	1.0		µg/L	1	2/12/2020 8:23:20 PM

Lab SampleID: 200206036-034 **Collection Date:** 2/6/2020
Client Sample ID: WES-34 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/6/2020)						
Lead	ND	1.0		µg/L	1	2/12/2020 8:27:05 PM

Lab SampleID: 200206036-035 **Collection Date:** 2/6/2020
Client Sample ID: WES-35 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/6/2020)						
Lead	ND	1.0		µg/L	1	2/12/2020 8:30:50 PM

Adirondack Environmental Services, Inc

Date: 19-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Westmere Elementary

LabWork Order: 200206036
PO#: 197320

Lab SampleID: 200206036-036**Collection Date:** 2/6/2020**Client Sample ID:** WES-36**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/6/2020)

Lead	ND	1.0		µg/L	1	2/12/2020 8:34:35 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200206036-037**Collection Date:** 2/6/2020**Client Sample ID:** WES-37**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/6/2020)

Lead	ND	1.0		µg/L	1	2/12/2020 8:38:20 PM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200206036-038**Collection Date:** 2/6/2020**Client Sample ID:** WES-38**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/6/2020)

Lead	2.3	1.0		µg/L	1	2/12/2020 8:42:04 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 200206036-039**Collection Date:** 2/6/2020**Client Sample ID:** WES-39**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/6/2020)

Lead	2.0	1.0		µg/L	1	2/12/2020 8:45:47 PM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 200206036-040**Collection Date:** 2/6/2020**Client Sample ID:** WES-40**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/6/2020)

Lead	1.2	1.0		µg/L	1	2/12/2020 8:56:58 PM
------	-----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 19-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Westmere Elementary

LabWork Order: 200206036
PO#: 197320

Lab SampleID: 200206036-041 **Collection Date:** 2/6/2020
Client Sample ID: WES-41 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/6/2020)						
Lead	ND	1.0		µg/L	1	2/12/2020 9:08:09 PM

Lab SampleID: 200206036-042 **Collection Date:** 2/6/2020
Client Sample ID: WES-42 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/6/2020)						
Lead	1.2	1.0		µg/L	1	2/12/2020 9:19:22 PM

Lab SampleID: 200206036-043 **Collection Date:** 2/6/2020
Client Sample ID: WES-43 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/6/2020)						
Lead	ND	1.0		µg/L	1	2/12/2020 9:23:07 PM

Lab SampleID: 200206036-044 **Collection Date:** 2/6/2020
Client Sample ID: WES-44 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/6/2020)						
Lead	ND	1.0		µg/L	1	2/12/2020 9:26:52 PM

Lab SampleID: 200206036-045 **Collection Date:** 2/6/2020
Client Sample ID: WES-46 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/6/2020)						
Lead	1.8	1.0		µg/L	1	2/12/2020 9:30:38 PM

Adirondack Environmental Services, Inc

Date: 19-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Westmere Elementary

LabWork Order: 200206036
PO#: 197320

Lab SampleID: 200206036-046 **Collection Date:** 2/6/2020
Client Sample ID: WES-47 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/6/2020)						
Lead	ND	1.0		µg/L	1	2/12/2020 9:41:50 PM

Lab SampleID: 200206036-047 **Collection Date:** 2/6/2020
Client Sample ID: WES-48 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/6/2020)						
Lead	ND	1.0		µg/L	1	2/12/2020 9:45:33 PM

Lab SampleID: 200206036-048 **Collection Date:** 2/6/2020
Client Sample ID: WES-49 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/6/2020)						
Lead	2.9	1.0		µg/L	1	2/12/2020 9:49:17 PM

Lab SampleID: 200206036-049 **Collection Date:** 2/6/2020
Client Sample ID: WES-50 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/6/2020)						
Lead	ND	1.0		µg/L	1	2/12/2020 9:53:02 PM

Lab SampleID: 200206036-050 **Collection Date:** 2/6/2020
Client Sample ID: WES-51 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/6/2020)						
Lead	7.7	1.0		µg/L	1	2/12/2020 9:56:46 PM

Adirondack Environmental Services, Inc

Date: 19-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Westmere Elementary

LabWork Order: 200206036
PO#: 197320

Lab SampleID: 200206036-051 **Collection Date:** 2/6/2020
Client Sample ID: WES-52 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: **SM**
(Prep: - 2/6/2020)

Lead	3.2	1.0		µg/L	1	2/12/2020 10:00:30 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 200206036-052 **Collection Date:** 2/6/2020
Client Sample ID: WES-53 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: **SM**
(Prep: - 2/6/2020)

Lead	ND	1.0		µg/L	1	2/12/2020 10:11:43 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 200206036-053 **Collection Date:** 2/6/2020
Client Sample ID: WES-54 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: **SM**
(Prep: - 2/6/2020)

Lead	1.9	1.0		µg/L	1	2/12/2020 10:15:28 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 200206036-054 **Collection Date:** 2/6/2020
Client Sample ID: WES-55 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: **SM**
(Prep: - 2/6/2020)

Lead	5.0	1.0		µg/L	1	2/12/2020 10:26:40 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 200206036-055 **Collection Date:** 2/6/2020
Client Sample ID: WES-56 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: **SM**
(Prep: - 2/6/2020)

Lead	1.1	1.0		µg/L	1	2/12/2020 10:30:26 PM
------	-----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 19-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Westmere Elementary

LabWork Order: 200206036
PO#: 197320

Lab SampleID: 200206036-056**Collection Date:** 2/6/2020**Client Sample ID:** WES-57**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/6/2020)

Lead	2.2	1.0		µg/L	1	2/12/2020 10:34:10 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 200206036-057**Collection Date:** 2/6/2020**Client Sample ID:** WES-58**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/6/2020)

Lead	ND	1.0		µg/L	1	2/12/2020 10:37:55 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 200206036-058**Collection Date:** 2/6/2020**Client Sample ID:** WES-59**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/6/2020)

Lead	ND	1.0		µg/L	1	2/12/2020 10:41:39 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 200206036-059**Collection Date:** 2/6/2020**Client Sample ID:** WES-60**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/6/2020)

Lead	1.9	1.0		µg/L	1	2/12/2020 10:45:23 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 200206036-060**Collection Date:** 2/6/2020**Client Sample ID:** WES-61**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/6/2020)

Lead	ND	1.0		µg/L	1	2/12/2020 10:49:07 PM
------	----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 19-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Westmere Elementary

LabWork Order: 200206036
PO#: 197320

Lab SampleID: 200206036-061**Collection Date:** 2/6/2020**Client Sample ID:** WES-63**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/6/2020)

Lead	2.2	1.0		µg/L	1	2/13/2020 10:19:43 PM
Lead	2.6	1.0		µg/L	1	2/12/2020 11:00:21 PM

Lab SampleID: 200206036-062**Collection Date:** 2/6/2020**Client Sample ID:** WES-64**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/6/2020)

Lead	ND	1.0		µg/L	1	2/12/2020 11:19:03 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 200206036-063**Collection Date:** 2/6/2020**Client Sample ID:** WES-65**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/6/2020)

Lead	1.2	1.0		µg/L	1	2/12/2020 11:22:49 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 200206036-064**Collection Date:** 2/6/2020**Client Sample ID:** WES-66**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/6/2020)

Lead	3.4	1.0		µg/L	1	2/12/2020 11:26:33 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 200206036-065**Collection Date:** 2/6/2020**Client Sample ID:** WES-67**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/6/2020)

Lead	ND	1.0		µg/L	1	2/12/2020 11:30:18 PM
------	----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 19-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Westmere Elementary

LabWork Order: 200206036
PO#: 197320

Lab SampleID: 200206036-066**Collection Date:** 2/6/2020**Client Sample ID:** WES-69**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/6/2020)

Lead	ND	1.0		µg/L	1	2/12/2020 11:34:02 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 200206036-067**Collection Date:** 2/6/2020**Client Sample ID:** WES-70**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/6/2020)

Lead	ND	1.0		µg/L	1	2/12/2020 11:37:47 PM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 200206036-068**Collection Date:** 2/6/2020**Client Sample ID:** WES-71**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/6/2020)

Lead	2.1	1.0		µg/L	1	2/12/2020 11:41:31 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 200206036-069**Collection Date:** 2/6/2020**Client Sample ID:** WES-72**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/6/2020)

Lead	2.3	1.0		µg/L	1	2/12/2020 11:45:16 PM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 200206036-070**Collection Date:** 2/6/2020**Client Sample ID:** WES-73**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/6/2020)

Lead	ND	1.0		µg/L	1	2/12/2020 11:56:28 PM
------	----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 19-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Westmere Elementary

LabWork Order: 200206036
PO#: 197320

Lab SampleID: 200206036-071 **Collection Date:** 2/6/2020
Client Sample ID: WES-74 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: **SM**
(Prep: - 2/6/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 12:00:13 AM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 200206036-072 **Collection Date:** 2/6/2020
Client Sample ID: WES-75 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: **SM**
(Prep: - 2/6/2020)

Lead	1.5	1.0		µg/L	1	2/13/2020 12:11:28 AM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 200206036-073 **Collection Date:** 2/6/2020
Client Sample ID: WES-76 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: **SM**
(Prep: - 2/6/2020)

Lead	1.6	1.0		µg/L	1	2/13/2020 12:15:14 AM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 200206036-074 **Collection Date:** 2/6/2020
Client Sample ID: WES-78 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: **SM**
(Prep: - 2/6/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 12:18:59 AM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 200206036-075 **Collection Date:** 2/6/2020
Client Sample ID: WES-79 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: **SM**
(Prep: - 2/6/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 12:22:44 AM
------	----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 19-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Westmere Elementary

LabWork Order: 200206036
PO#: 197320

Lab SampleID: 200206036-076 **Collection Date:** 2/6/2020
Client Sample ID: WES-80 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: **SM**
(Prep: - 2/6/2020)

Lead	1.6	1.0		µg/L	1	2/13/2020 12:26:28 AM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 200206036-077 **Collection Date:** 2/6/2020
Client Sample ID: WES-81 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: **SM**
(Prep: - 2/6/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 12:30:13 AM
------	----	-----	--	------	---	-----------------------

Lab SampleID: 200206036-078 **Collection Date:** 2/6/2020
Client Sample ID: WES-82 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: **SM**
(Prep: - 2/6/2020)

Lead	1.2	1.0		µg/L	1	2/13/2020 12:33:58 AM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 200206036-079 **Collection Date:** 2/6/2020
Client Sample ID: WES-83 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: **SM**
(Prep: - 2/6/2020)

Lead	1.0	1.0		µg/L	1	2/13/2020 12:45:10 AM
------	-----	-----	--	------	---	-----------------------

Lab SampleID: 200206036-080 **Collection Date:** 2/6/2020
Client Sample ID: WES-84 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4 Analyst: **SM**
(Prep: - 2/6/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 12:48:55 AM
------	----	-----	--	------	---	-----------------------

Adirondack Environmental Services, Inc

Date: 19-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Westmere Elementary

LabWork Order: 200206036
PO#: 197320

Lab SampleID: 200206036-081 **Collection Date:** 2/6/2020
Client Sample ID: WES-85 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/6/2020)						
Lead	1.0	1.0		µg/L	1	2/13/2020 1:00:10 AM

Lab SampleID: 200206036-082 **Collection Date:** 2/6/2020
Client Sample ID: WES-86 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/6/2020)						
Lead	1.8	1.0		µg/L	1	2/13/2020 1:11:26 AM

Lab SampleID: 200206036-083 **Collection Date:** 2/6/2020
Client Sample ID: WES-87 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/6/2020)						
Lead	1.3	1.0		µg/L	1	2/13/2020 1:15:11 AM

Lab SampleID: 200206036-084 **Collection Date:** 2/6/2020
Client Sample ID: WES-88 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/6/2020)						
Lead	5.1	1.0		µg/L	1	2/13/2020 1:18:56 AM

Lab SampleID: 200206036-085 **Collection Date:** 2/6/2020
Client Sample ID: WES-89 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/6/2020)						
Lead	2.4	1.0		µg/L	1	2/13/2020 1:22:41 AM

Adirondack Environmental Services, Inc

Date: 19-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Westmere Elementary

LabWork Order: 200206036
PO#: 197320

Lab SampleID: 200206036-086 **Collection Date:** 2/6/2020
Client Sample ID: WES-90 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/6/2020)						
Lead	3.1	1.0		µg/L	1	2/13/2020 1:26:26 AM

Lab SampleID: 200206036-087 **Collection Date:** 2/6/2020
Client Sample ID: WES-91 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/6/2020)						
Lead	1.3	1.0		µg/L	1	2/13/2020 1:30:11 AM

Lab SampleID: 200206036-088 **Collection Date:** 2/6/2020
Client Sample ID: WES-92 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/6/2020)						
Lead	1.7	1.0		µg/L	1	2/13/2020 1:33:57 AM

Lab SampleID: 200206036-089 **Collection Date:** 2/6/2020
Client Sample ID: WES-93 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/6/2020)						
Lead	ND	1.0		µg/L	1	2/13/2020 1:37:42 AM

Lab SampleID: 200206036-090 **Collection Date:** 2/6/2020
Client Sample ID: WES-94 **Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4 Analyst: SM (Prep: - 2/6/2020)						
Lead	3.6	1.0		µg/L	1	2/13/2020 1:41:27 AM

Adirondack Environmental Services, Inc

Date: 19-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Westmere Elementary

LabWork Order: 200206036
PO#: 197320

Lab SampleID: 200206036-091**Collection Date:** 2/6/2020**Client Sample ID:** WES-95**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/6/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 2:00:11 AM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200206036-092**Collection Date:** 2/6/2020**Client Sample ID:** WES-96**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/6/2020)

Lead	1.0	1.0		µg/L	1	2/13/2020 2:11:28 AM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 200206036-093**Collection Date:** 2/6/2020**Client Sample ID:** WES-97**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/6/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 2:15:13 AM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200206036-094**Collection Date:** 2/6/2020**Client Sample ID:** WES-97A**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/6/2020)

Lead	5.2	1.0		µg/L	1	2/13/2020 2:18:59 AM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 200206036-095**Collection Date:** 2/6/2020**Client Sample ID:** WES-98**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/6/2020)

Lead	2.3	1.0		µg/L	1	2/13/2020 2:22:44 AM
------	-----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc

Date: 19-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Westmere Elementary

LabWork Order: 200206036
PO#: 197320

Lab SampleID: 200206036-096**Collection Date:** 2/6/2020**Client Sample ID:** WES-99**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/6/2020)

Lead	1.4	1.0		µg/L	1	2/13/2020 2:26:30 AM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 200206036-097**Collection Date:** 2/6/2020**Client Sample ID:** WES-100**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/6/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 2:30:16 AM
------	----	-----	--	------	---	----------------------

Lab SampleID: 200206036-098**Collection Date:** 2/6/2020**Client Sample ID:** WES-101**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/6/2020)

Lead	1.3	1.0		µg/L	1	2/13/2020 2:34:01 AM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 200206036-099**Collection Date:** 2/6/2020**Client Sample ID:** WES-102**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/6/2020)

Lead	3.6	1.0		µg/L	1	2/13/2020 2:45:15 AM
------	-----	-----	--	------	---	----------------------

Lab SampleID: 200206036-100**Collection Date:** 2/6/2020**Client Sample ID:** WES-103**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**

(Prep: - 2/6/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 2:49:00 AM
------	----	-----	--	------	---	----------------------

Adirondack Environmental Services, Inc**Date:** 19-Feb-20

CLIENT: Guilderland CSD
Project: 2020 Lead Sampling and Analysis
Westmere Elementary

LabWork Order: 200206036
PO#: 197320

Lab SampleID: 200206036-101**Collection Date:** 2/6/2020**Client Sample ID:** WES-104**Matrix:** DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
----------	--------	----	------	-------	----	---------------

ICP/MS - EPA 200.8 REV 5.4Analyst: **SM**(**Prep:** - 2/6/2020)

Lead	ND	1.0		µg/L	1	2/13/2020 2:52:46 AM
------	-----------	-----	--	------	---	----------------------



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#:

200206036

COC Reference:

1378

A full service analytical research laboratory offering solutions to environmental concerns

AES Sample Number		Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis
Matrix					C	G				
001	WES-01	x	2/6/20	0526	PW		X	1	0	Lead
002	WES-02	x	2/6/20	0526	PW		X	1	0	Lead
003	WES-03	x	2/6/20	0527	PW		X	1	0	Lead
004	WES-03A	x	2/6/20	0528	PW		X	1	0	Lead
005	WES-04	x	2/6/20	0528	PW		X	1	0	Lead
006	WES-05	x	2/6/20	0523	PW		X	1	0	Lead
007	WES-06	x	2/6/20	0523	PW		X	1	0	Lead
008	WES-07	x	2/6/20	0522	PW		X	1	0	Lead
009	WES-08	x	2/6/20	0522	PW		X	1	0	Lead
010	WES-10	x	2/6/20	0523	PW		X	1	0	Lead
011	WES-11	x	2/6/20	0517	PW		X	1	0	Lead
012	WES-12	x	2/6/20	0517	PW		X	1	0	Lead
013	WES-13	x	2/6/20	0520	PW		X	1	0	Lead
014	WES-14	x	2/6/20	0518	PW		X	1	0	Lead
015	WES-15	x	2/6/20	0521	PW		X	1	0	Lead
016	WES-16	x	2/6/20	0521	PW		X	1	0	Lead

Shipment Arrived Via: FedEx UPS Client <u>AES</u> Other:		Special Instructions/Remarks:	
Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day <u>Standard</u>			
NOTE: Samples received after 3:30pm are considered next business day.			

Relinquished by: (Signature)		Received by: (Signature)		Date	Time
Relinquished by: (Signature)		Received by: (Signature)		Date	Time
Relinquished by: (Signature)		Received for Laboratory by:		Date	Time
				2/6/20	12:16P

Sample Temperature Ambient Notes: Ice preservation not required	Properly Preserved: <u>Y</u> / N	Received Within Holding Times: <u>Y</u> / N Notes:
	0=None 5=NH ₄ Cl 1=H ₂ SO ₄ pH<2 6=Ascorbic Acid 2=HNO ₃ pH<2 7=FAS 3=HCl pH<2 8=ZnAc/NaC 4=Na ₂ S ₂ O ₃ 9=NaOH pH 10=Other	
Bottles AES: <u>Y</u> / N		



200206036



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#:

200206036

COC Reference:

1378

A full service analytical research laboratory offering solutions to environmental concerns

AES Sample Number		Client Sample Identification & Location		Date	Time	Sample Type			# of Cont's	Preservative	Analysis
						Matrix	C	G			
017	WES- 17			2/6/20	0515	PW		X	1	0	Lead
018	WES- 18			2/6/20	0515	PW		X	1	0	Lead
019	WES- 19			2/6/20	0516	PW		X	1	0	Lead
020	WES- 20			2/6/20	0516	PW		X	1	0	Lead
021	WES- 21			2/6/20	0512	PW		X	1	0	Lead
022	WES- 22			2/6/20	0512	PW		X	1	0	Lead
023	WES- 23			2/6/20	0511	PW		X	1	0	Lead
024	WES- 24			2/6/20	0512	PW		X	1	0	Lead
025	WES- 25			2/6/20	0508	PW		X	1	0	Lead
026	WES- 26			2/6/20	0508	PW		X	1	0	Lead
027	WES- 27			2/6/20	0510	PW		X	1	0	Lead
028	WES- 28			2/6/20	0510	PW		X	1	0	Lead
029	WES- 29			2/6/20	0507	PW		X	1	0	Lead
030	WES- 30			2/6/20	0506	PW		X	1	0	Lead
031	WES- 31			2/6/20	0506	PW		X	1	0	Lead
032	WES- 32			2/6/20	0505	PW		X	1	0	Lead

Shipment Arrived Via: FedEx UPS Client AES Other:		Special Instructions/Remarks:	
Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day <u>Standard</u>			
NOTE: Samples received after 3:30pm are considered next business day.			

Relinquished by: (Signature)		Received by: (Signature)		Date	Time
Relinquished by: (Signature)		Received by: (Signature)		Date	Time
Relinquished by: (Signature)		Received for Laboratory by:		Date	Time
				2/6/20	12:16 PM

Sample Temperature Ambient Notes: Ice preservation not required	Properly Preserved: <u>Y</u> / N	Received Within Holding Times: <u>Y</u> / N Notes:
	Bottles AES: <u>Y</u> / N	

0=None
1=H₂SO₄ pH<2
2=HNO₃ pH<2
3=HCl pH<2
4=Na₂S₂O₃

5=NH₄Cl
6=Ascorbic Acid
7=FAS
8=ZnAc/NaOH pH>9
9=NaOH pH>10
10=Other



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#:

200206036

COC Reference:

1378

A full service analytical research laboratory offering solutions to environmental concerns

AES Sample Number		Client Sample Identification & Location	Date	Time	Sample Type			# of Cont's	Preservative	Analysis	
					Matrix	C	G				
033	WES-	33 r	2/6/20	0505	PW		X	1	0	Lead	
034	WES-	34 r	2/6/20	0505	PW		X	1	0	Lead	
035	WES-	35 r	2/6/20	0505	PW		X	1	0	Lead	
036	WES-	36 r	2/6/20	0505	PW		X	1	0	Lead	
037	WES-	37 r	2/6/20	0505	PW		X	1	0	Lead	
038	WES-	38 r	2/6/20	0504	PW		X	1	0	Lead	
039	WES-	39 r	2/6/20	0504	PW		X	1	0	Lead	
040	WES-	40 r	2/6/20	0504	PW		X	1	0	Lead	
041	WES-	41 r	2/6/20	0504	PW		X	1	0	Lead	
042	WES-	42 r	2/6/20	0502	PW		X	1	0	Lead	
043	WES-	43 r	2/6/20	0500	PW		X	1	0	Lead	
044	WES-	44 r	2/6/20	0500	PW		X	1	0	Lead	
045	WES-	46 r	2/6/20	0459	PW		X	1	0	Lead	
046	WES-	47 r	2/6/20	0459	PW		X	1	0	Lead	
047	WES-	48 r	2/6/20	0459	PW		X	1	0	Lead	
048	WES-	49 r	2/6/20	0613	PW		X	1	0	Lead	
Shipment Arrived Via: FedEx UPS Client AES Other:					Special Instructions/Remarks:						
Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day <u>Standard</u>											
NOTE: Samples received after 3:30pm are considered next business day.											
Relinquished by: (Signature)					Received by: (Signature)				Date	Time	
Relinquished by: (Signature)					Received by: (Signature)				Date	Time	
Relinquished by: (Signature)					Received for Laboratory by:				Date	Time	
Sample Temperature Ambient Notes: Ice preservation not required					Properly Preserved: Y / N 0=None 5=NH ₄ Cl 1=H ₂ SO ₄ pH<2 6=Ascorbic Acid 2=HNO ₃ pH<2 7=FAS 3=HCl pH<2 8=ZnAc/NaOH pH>9 4=Na ₂ S ₂ O ₃ 9=NaOH pH>10 10=Other				Received Within Holding Times: Y / N Notes:		
Bottles AES: Y / N											



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#:

200206036

COC Reference:

1378

A full service analytical research laboratory offering solutions to environmental concerns

AES Sample Number		Client Sample Identification & Location		Date	Time	Sample Type			# of Cont's	Preservative	Analysis
						Matrix	C	G			
049	WES- 50 *	2/6/20	0554	PW		X			1	0	Lead
050	WES- 51 *	2/6/20	0554	PW		X			1	0	Lead
051	WES- 52 *	2/6/20	0556	PW		X			1	0	Lead
052	WES- 53 *	2/6/20	0556	PW		X			1	0	Lead
053	WES- 54 *	2/6/20	0600	PW		X			1	0	Lead
054	WES- 55 *	2/6/20	0600	PW		X			1	0	Lead
055	WES- 56 *	2/6/20	0601	PW		X			1	0	Lead
056	WES- 57 *	2/6/20	0601	PW		X			1	0	Lead
057	WES- 58 *	2/6/20	0603	PW		X			1	0	Lead
058	WES- 59 *	2/6/20	0603	PW		X			1	0	Lead
059	WES- 60 *	2/6/20	0602	PW		X			1	0	Lead
060	WES- 61 *	2/6/20	0554	PW		X			1	0	Lead
061	WES- 63 *	2/6/20	0554	PW		X			1	0	Lead
062	WES- 64 *	2/6/20	0553	PW		X			1	0	Lead
063	WES- 65 *	2/6/20	0553	PW		X			1	0	Lead
064	WES- 66 *	2/6/20	0553	PW		X			1	0	Lead

Shipment Arrived Via: FedEx UPS Client <u>AES</u> Other:		Special Instructions/Remarks:	
Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day <u>Standard</u>			
NOTE: Samples received after 3:30pm are considered next business day.			

Relinquished by: (Signature)		Received by: (Signature)		Date	Time
Relinquished by: (Signature)		Received by: (Signature)		Date	Time
Relinquished by: (Signature)		Received for Laboratory by:		Date	Time
				2/6/20	12:16 PM

Sample Temperature Ambient Notes: Ice preservation not required	Properly Preserved: Y / N 0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 3=HCl pH<2 4=Na ₂ S ₂ O ₃ 5=NH ₄ Cl 6=Ascorbic Acid 7=FAS 8=ZnAc/NaOH pH>9 9=NaOH pH>10 10=Other	Received Within Holding Times: Y / N Notes:
Bottles AES: Y / N		



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#:

200206036

COC Reference:

1378

A full service analytical research laboratory offering solutions to environmental concerns

AES Sample Number		Client Sample Identification & Location		Date	Time	Sample Type			# of Cont's	Preservative	Analysis
						Matrix	C	G			
065		WES- 67		2/6/20	0555	PW		X	1	0	Lead
066		WES- 69		2/6/20	0555	PW		X	1	0	Lead
067		WES- 70		2/6/20	0550	PW		X	1	0	Lead
068		WES- 71		2/6/20	0552	PW		X	1	0	Lead
069		WES- 72		2/6/20	0552	PW		X	1	0	Lead
070		WES- 73		2/6/20	0552	PW		X	1	0	Lead
071		WES- 74		2/6/20	0552	PW		X	1	0	Lead
072		WES- 75		2/6/20	0552	PW		X	1	0	Lead
073		WES- 76		2/6/20	0548	PW		X	1	0	Lead
074		WES- 78		2/6/20	0547	PW		X	1	0	Lead
075		WES- 79		2/6/20	0546	PW		X	1	0	Lead
076		WES- 80		2/6/20	0545	PW		X	1	0	Lead
077		WES- 81		2/6/20	0545	PW		X	1	0	Lead
078		WES- 82		2/6/20	0545	PW		X	1	0	Lead
079		WES- 83		2/6/20	0545	PW		X	1	0	Lead
080		WES- 84		2/6/20	0545	PW		X	1	0	Lead

Shipment Arrived Via: FedEx UPS Client <u>AES</u> Other:				Special Instructions/Remarks:					
Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day <u>Standard</u>									
NOTE: Samples received after 3:30pm are considered next business day.									
Relinquished by: (Signature) <u>REN</u>				Received by: (Signature)				Date	Time
Relinquished by: (Signature)				Received by: (Signature)				Date	Time
Relinquished by: (Signature)				Received for Laboratory by: <u>J. M.</u>				Date <u>2/6/20</u>	Time <u>12:16 PM</u>

Sample Temperature Ambient Notes: Ice preservation not required		Properly Preserved: Y / N 0=None 5=NH ₄ Cl 1=H ₂ SO ₄ pH<2 6=Ascorbic Acid 2=HNO ₃ pH<2 7=FAS 3=HCl pH<2 8=ZnAc/NaOH pH>9 4=Na ₂ S ₂ O ₃ 9=NaOH pH>10 10=Other		Received Within Holding Times: Y / N Notes:	
Bottles AES: Y / N					



314 North Pearl Street
Albany, NY 12207
518-434-4546 / FAX: 518-434-0891

EXPERIENCE IS THE SOLUTION

CHAIN OF CUSTODY RECORD

AES Work Order#:

200006036

COC Reference:

1378

A full service analytical research laboratory offering solutions to environmental concerns

AES Sample Number		Client Sample Identification & Location		Date	Time	Sample Type			# of Cont's	Preservative	Analysis
						Matrix	C	G			
080		WES- 85		2/6/20	0545	PW		X	1	0	Lead
081		WES- 86		2/6/20	0545	PW		X	1	0	Lead
082		WES- 87		2/6/20	0545	PW		X	1	0	Lead
083		WES- 88		2/6/20	0547	PW		X	1	0	Lead
084		WES- 89		2/6/20	0547	PW		X	1	0	Lead
085		WES- 90		2/6/20	0546	PW		X	1	0	Lead
086		WES- 91		2/6/20	0545	PW		X	1	0	Lead
087		WES- 92		2/6/20	0545	PW		X	1	0	Lead
088		WES- 93		2/6/20	0542	PW		X	1	0	Lead
089		WES- 94		2/6/20	0542	PW		X	1	0	Lead
090		WES- 95		2/6/20	0542	PW		X	1	0	Lead
091		WES- 96		2/6/20	0529	PW		X	1	0	Lead
092		WES- 97		2/6/20	0528	PW		X	1	0	Lead
093		WES- 97A		2/6/20	0528	PW		X	1	0	Lead
094		WES- 98		2/6/20	0520	PW		X	1	0	Lead
095		WES- 99		2/6/20	0520	PW		X	1	0	Lead

Shipments Arrived Via: FedEx UPS Client ☒ AES Other:				Special Instructions/Remarks:			
Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day <u>Standard</u>							
NOTE: Samples received after 3:30pm are considered next business day.							
Relinquished by: (Signature) <u>PLR</u>				Received by: (Signature)			
Relinquished by: (Signature)				Received by: (Signature)			
Relinquished by: (Signature)				Received for Laboratory by:			

Sample Temperature Ambient Notes: Ice preservation not required		Properly Preserved: Y / N 0=None 1=H ₂ SO ₄ pH<2 2=HNO ₃ pH<2 3=HCl pH<2 4=Na ₂ S ₂ O ₃ 5=NH ₄ Cl 6=Ascorbic Acid 7=FAS 8=ZnAc/NaOH pH>9 9=NaOH pH>10 10=Other		Received Within Holding Times: Y / N Notes:	
Bottles AES: <u>Y</u> / N					



CHAIN OF CUSTODY RECORD

AES Work Order#:

2002 0603 6

COC Reference:

1378

A full service analytical research laboratory offering solutions to environmental concerns

Guilderland Central School District						Address:										
Tim Murphy, Clifford Nooney						Project Name (Location): Westmere Elementary				Samplers Name: <i>Michael Wilsey / Patrick Dornell</i>						
Client Phone #:						Client PO #:				Samplers Signature: <i>[Signature]</i>						
Client Email:																
AES Sample Number	Client Sample Identification & Location					Date	Time	Sample Type Matrix C G			# of Cont's	Preservative	Analysis			
096	WES- 100 *					2/6/20	0511	PW		X	1	0	Lead			
097	WES- 101 *					2/6/20	0606	PW		X	1	0	Lead			
098	WES- 102 *					2/6/20	0605	PW		X	1	0	Lead			
099	WES- 103 *					2/6/20	0602	PW		X	1	0	Lead			
100	WES- 104 *					2/6/20	0605	PW		X	1	0	Lead			
2/6/20	WES-							PW		X	1	0	Lead			
2/6/20	WES-							PW		X	1	0	Lead			
	WES-							PW		X	1	0	Lead			
	WES-							PW		X	1	0	Lead			
	WES-							PW		X	1	0	Lead			
	WES-							PW		X	1	0	Lead			
	WES-							PW		X	1	0	Lead			
	WES-							PW		X	1	0	Lead			
	WES-							PW		X	1	0	Lead			
	WES-							PW		X	1	0	Lead			
	WES-							PW		X	1	0	Lead			
	WES-							PW		X	1	0	Lead			
	WES-							PW		X	1	0	Lead			
	WES-							PW		X	1	0	Lead			
	WES-							PW		X	1	0	Lead			
	WES-							PW		X	1	0	Lead			

Shipment Arrived Via: FedEx UPS Client AES Other:					Special Instructions/Remarks:							
Turnaround Time Requested: 1 Day 2 Day 3 Day 5 Day Standard												
NOTE: Samples received after 3:30pm are considered next business day.												
					PLEASE FILL ALL PINK SHADED AREAS							
Relinquished by: (Signature) [Signature]					Received by: (Signature)					Date	Time	
Relinquished by: (Signature)					Received by: (Signature)					Date	Time	
Relinquished by: (Signature)					Received for Laboratory by:					Date	Time	
Sample Temperature Ambient Notes: Ice preservation not required					Properly Preserved: Y / N 0=None 5=NH ₄ Cl 1=H ₂ SO ₄ pH<2 6=Ascorbic Acid 2=HNO ₃ pH<2 7=FAS 3=HCl pH<2 8=ZnAc/NaOH pH>9 4=Na ₂ S ₂ O ₃ 9=NaOH pH>10 10=Other _____					Received Within Holding Times: Y / N Notes:		
Bottles AES: Y / N												



Experience is the solution

314 North Pearl Street • Albany, New York 12207 • (518) 434-4546 • Fax (518) 434-0891

TERMS, CONDITIONS & LIMITATIONS

All service rendered by the **Adirondack Environmental Services, Inc.** are undertaken and all rates are based upon the following terms:

- (a) Neither **Adirondack Environmental Services, Inc.**, nor any of its employees, agents or sub-contractors shall be liable for any loss or damage arising out of **Adirondack Environmental Services, Inc.**'s performance or nonperformance, whether by way of negligence or breach of contract, or otherwise, in any amount greater than twice the amount billed to the customer for the work leading to the claim of the customer. Said remedy shall be the sole and exclusive remedy against **Adirondack Environmental Services, Inc.** arising out of its work.
- (b) All claims made must be in writing within forty-five (45) days after delivery of the **Adirondack Environmental Services, Inc.** report regarding said work or such claim shall be deemed or irrevocably waived.
- (c) **Adirondack Environmental Services, Inc.** reports are submitted in writing and are for our customers only. Our customers are considered to be only those entities being billed for our services. Acquisition of an **Adirondack Environmental Services, Inc.** report by other than our customer does not constitute a representation of **Adirondack Environmental Services, Inc.** as to the accuracy of the contents thereof.
- (d) In no event shall **Adirondack Environmental Services, Inc.**, its employees, agents or sub-contractors be responsible for consequential or special damages of any kind or in any amount.
- (e) No deviation from the terms set forth herein shall bind **Adirondack Environmental Services, Inc.** unless in writing and signed by a Director of **Adirondack Environmental Services, Inc.**
- (f) Results pertain only to items analyzed. Information supplied by client is assumed to be correct. This information may be used on reports and in calculations and **Adirondack Environmental Services, Inc.** is not responsible for the accuracy of this information.
- (g) Payments by Credit Card/Purchase Cards are subject to a 3% additional charge.