

AES Water Outlets Testing 2024-2025

Room	Outlet	Sample ID	Aug. 2024	Mitigation	Nov. 2024	Mitigation Re-check	Dec. 2025
Hallway outside Nurse	Fountain of combo	AES-1A	<1.0				
Hallway outside Nurse	Bottle Fill of combo	AES-1B	<1.0				
Nurse	Sink	AES-2	1				
211	Sink	AES-3	<1.0				
210	Sink	AES-4	<1.0				
209	Sink	AES-5	<1.0				
208	Sink	AES-6	1.5				
207	Sink	AES-7	<1.0				
206	Sink	AES-8	16.5	shut-offs, faucet,lines	2.5		
205	Sink	AES-9	3.1				
204	Sink	AES-10	<1.0				
203	Sink	AES-11	<1.0				
202	Sink	AES-12	<1.0				
201	Sink	AES-13	2.3				
182, thru Copy room	Sink	AES-14	21.6	shut-offs* faucet,lines	22.3	*New shutoffs were after old ones	16.5
Kitchen	Sink	AES-15A	3.6				
Kitchen	Sink	AES-15B	1.1				
Kitchen	Sink	AES 15C	3.5				
Library	Sink	AES-16	<1.0				
Instrumental	Sink	AES-22	1.4				
304	Sink	AES-18	<1.0				
305	Sink	AES-19A	<1.0				
305	Sink	AES-19B	<1.0				
306	Sink	AES-20	<1.0				
307	Sink	AES-21	1.9				
301 PE office	Sink	AES-22	1.4				
Hallway near 401	Fountain of combo	AES-23A	Repaired	Sample on 2nd round	<1.0		
Hallway near 401	Bottle Fill of combo	AES-23B	<1.0				
400	Sink (removing fountain)	AES-24	2.1				
401	Sink	AES-25	17.9	shut-offs, faucet,lines	325	Confirmed last mitigation work	<1.0
402	Sink	AES-26	1.2				
403	Sink	AES-27	<1.0				
404	Sink	AES-28	<1.0				
405	Sink (removing fount.)	AES-29	<1.0				
406	Sink (removing fount.)	AES-30	<1.0				
407	Sink (removing fount.)	AES-31	<1.0				
408	Sink (removing fount.)	AES-32	<1.0				
409	Sink (didn't sample fount.)	AES 33	<1.0				