

FMS Water Outlets Testing 2024-2025

First Floor:	Outlets	ID	Aug. 2024	Mitigation	Nov. 2024	Mitigation Re-check	Dec. 2025
508	Sink	FMS 1	9.1	Shut-off, faucet	12.1	faucet and just cold shut off new	6.3
Circle across from 507	Fountain, regular	FMS 2	2.5				
504	Sink	FMS 3	1.3				
Nurse's office	Sink	FMS 4	<1.0				
Nurse, side lounge room	Sink (marked but test)	FMS 5	92	shutoff, lines, filter	5.8	All new	3.5
Circle across from 501	Fountain regular , left	FMS 6A	<1.0				
Circle across from 501	Fountain regular, right	FMS 6B	<1.0				
Kitchen	Sink, near hall	FMS 7A	6.9	filter, lines	<1.0		
Kitchen	Sink	FMS 7B	1.8				
Kitchen	Sink	FMS 7C	4.4				
Kitchen	Sink	FMS 7D	<1.0				
Kitchen	Sink	FMS 7E	<1.0				
Kitchen	Sink	FMS 7F	<1.0				
Cafeteria	Fountain combo, foun.	FMS 8A	<1.0				
Cafeteria	Fountain combo, bottle	FMS 8B	<1.0				
533 Principal's Conference	Sink	FMS 9	1.9				
Main Entrance Lobby	Fountain/regular	FMS 10	<1.0				
Hiawatha 300	Sink	FMS 11A	1.5				
Hiawatha 300	Fountain	FMS 11B	1.7				
Hiawatha 301, Not science	Sink, stand alone	FMS 12M	<1.0				
Hiawatha 307	Sink	FMS 13	1.7				
Hiawatha 306	Sink	FMS 14A	<1.0				
Hiawatha 306	Fountain	FMS 14B	<1.0				
Hiawatha across from 306	Fountain combo, foun.	FMS 15A	<1.0				
Hiawatha across from 306	Fountain combo, sink	FMS 15B	<1.0				
Mohawk across from 209	Fountain, regular	FMS 16	<1.0				
Mohawk 200	Sink	FMS 17A	1				
Mohawk 200	Fountain	FMS 17B	1.3				
Mohawk 206, Not Science	Sink, stand alone	FMS 18M	1.5				
Tawasentha 108	Sink	FMS 19A	<1.0				
Tawasentha 108	Fountain	FMS 19B	<1.0				

Taw 103, Not Science	Sink, stand alone	FMS 20K	79.6	Pending				57.2
Hallway, between 103 and	Fountain combo, foun.	FMS 21A	<1.0					
Hallway, between 103 and	Fountain combo, bottle	FMS 21B	<1.0					
Tawasentha 101	Sink	FMS 22A	<1.0					
Tawasentha 101	Fountain	FMS 22B	3.8					
Tawasentha 100	Sink	FMS 23A	1.3					
Tawasentha 100	Fountain	FMS 23B	<1.0					
803 Gym	2 fountains, (Don't work)	N/A	N/A	Out of service				
Boy's Locker Room	Sink	FMS 25A	<1.0					
Boy's Locker Room	Fountain	FMS 25B	1.3					
Girl's Locker Room	Sink	FMS 26	2					
Hallway behind Girl's PE off	Fountain combo, foun.	FMS 27A	<1.0					
Hallway behind Girl's PE off	Fountain combo, bottle	FMS 27B	<1.0					
Hallway behind Boy's PE Of	Fountain combo, foun.	FMS 28A	<1.0					
Hallway behind Boy's PE Of	Fountain combo, bottle	FMS 28B	<1.0					
Seneca 409	Sink	FMS 29A	1.7					
Seneca 409	Fountain	FMS 29B	<1.0					
Seneca 408	Sink	FMS 30A	1.4					
Seneca 408	Fountain	FMS 30B	<1.0					
Seneca 404	Sink	FMS 31A	1.1					
Seneca 404	Fountain	FMS 31B	1.3					
Seneca 403	Sink	FMS 32A	1.6					
Seneca 403	Fountain	FMS 32B	1.4					
Seneca 402	Sink	FMS 33A	4.7					
Seneca 402	Fountain	FMS 33B	1.3					
Hallway across from Sececa	Fountain combo, foun.	FMS 34A	<1.0					
Hallway across from Seneca	Fountain, bottle filler	FMS 34B	<1.0					
Seneca 401	Sink	FMS 35A	3.7					
Seneca 401	Fountain	FMS 35B	<1.0					
Seneca 451	Sink	FMS 36A	1.9					
Seneca 451	Fountain	FMS 36B	<1.0					
Hallway across Seneca 451	Fountain, regular	FMS 37	<1.0					
Seneca 452	Sink	FMS 38A	<1.0					
Seneca 452	Fountain	FMS 38B	1.1					

Seneca 453	Sink	FMS 39A	1.8				
Seneca 453	Fountain	FMS 39B	<1.0				
Seneca 454	Sink	FMS 40	1.3				
Seneca 434 Faculty	Sink	FMS 41A	1.7				
Seneca 434 Faculty	Fountain	FMS 41B	3.4				
Seneca 455	Sink	FMS 42	2.3				
Hallway, to right of Sen 433	Fountain, regular	FMS 43	1.3				
Seneca 456	Sink	FMS 44A	1.1				
Seneca 456	Fountain	FMS 44B	<1.0				
Seneca 457	Sink	FMS 45A	2.5				
Seneca 457	Fountain	FMS 45B	<1.0				
Seneca 458	Sink	FMS 46A	1.4				
Seneca 458	Fountain	FMS 46B	<1.0				
Seneca 459	Sink	FMS 47A	1				
Seneca 459	Fountain	FMS 47B	<1.0				
Hallway Seneca left of 484	Fountain, regular	FMS 48	N/A	Sampled 2nd rd.	<1.0		
Taw136 faculty across 151	Sink	FMS 49	1.3				
Tawasentha 130	Sink	FMS 50	1.6				
Hallway across from Taw15	Fountain combo, foun.	FMS 51A	<1.0				
Hallway across from Taw15	Fountain combo, bottle	FMS 51B	<1.0				
Hallway across from Taw 15	Fountain combo, foun.	FMS 52A	<1.0				
Hallway across from Taw 15	Fountain combo, bottle	FMS 52B	<1.0				
Moh 232 Faculty across 253	Sink	FMS 53	9.3	shutoffs, faucet	12.6	Shut-offs and faucet are new	5
Hallway across from Moh 2	Fountain combo, foun.	FMS 54A	<1.0				
Hallway across from Moh 2	Fountain combo, bottle	FMS 54B	<1.0				
Hallway across from Hia353	Fountain combo, foun.	FMS 55A	<1.0				
Hallway across from Hia353	Fountain combo, bottle	FMS 55B	<1.0				
Circle, Library 631 faculty	Sink	FMS 56	1.4				
Hallway Circle, across 522	Fountain combo, foun.	FMS 57A	<1.0				
Hallway Circle, across 522	Fountain combo, bottle	FMS 57B	<1.0				
Circle 561	Small sink on right	FMS 58	2.5				
Circle 560	Sink	FMS 59A	3.7				
Circle 560	Sink	FMS 59B	1.4				
Circle 560	Sink	FMS 59C	2.2				

Circle 560	Sink	FMS 59D	3.1				
Circle 560	Sink	FMS 59E	2.1				
Circle 559	Sink	FMS 60A	1.7				
Circle 559	Sink	FMS 60B	1.8				
Circle 559	Sink	FMS 60C	1.4				
Circle 559	Sink	FMS 60D	1.5				
Circle 559	Sink	FMS 60E	2.3				
Hallway across from Circle	Fountain, increased	N/A	N/A	Sampled 2nd rd.	3.6		