

GHS Water Outlets Testing 2024-2025

Room	Outlet	ID	Aug. 2024	Mitigation	Nov. 2024	Mitigation Re-check	Dec. 2025
102	Sink	HS-2	3.9				
104	Sink	HS-3	2				
Hallway near 201	Fountain combo, fountain	HS-4A	<1.0				
Hallway near 201	Fountain combo, bottle filler	HS-4B	<1.0				
Hallway near 302	Fountain combo, fountain	HS 5A	11.5	Installed filter	<1.0		
Hallway near 302	Fountain combo, bottle filler	HS-5B	<1.0				
Faculty Room near 310	Sink	HS-6	2.2				
Hallway near 402	Fountain combo, fountain	HS-7A	<1.0				
Hallway near 402	Fountain combo, bottle filler	HS-7B	<1.0				
Office/lunchroom off of 401	1 Sink	HS-8	<1.0				
Library staff area	Sink	HS-11	4				
Auditorium hall near restrooms	Fountain, regular	HS-12	<1.0				
Auditorium hall near Library	Fountain combo, fountain	HS-13A	<1.0				
Auditorium hall near Library	Fountain combo, bottle filler	HS-13B	<1.0				
Main Office, conference room	Sink	HS-14	1.5				
Main Entrance near restrooms	Fountain, regular	HS-15A	1.9				
Main Entrance near restrooms	Fountain, regular	HS-15B	<1.0				
Cafeteria B, behind counter	Sink	HS-16	18.5	Installed filter	40.2	Date on filter 11/7/23	4.9
Cafeteria B	Fountain, regular	HS-17A	N/A	Was off, sample on 2nd	4.7		
Cafeteria B	Fountain, regular	HS-17B	N/A	Was off, sample on 2nd	4.7		
Kitchen	Three spicket sink, left	HS-18A	22.8	Replaced faucet	5.6	Confirmed Mitigation	4.1
Kitchen	Three spicket sink, middle	HS-18B	2.6				
Kitchen	Three spicket sink, right	HS-18C	3.1				
Kitchen	Sink near dishwasher	HS-18D	1				
Kitchen	Two spicket prep sink, left	HS-18E	2.4				
Kitchen	Two spicket prep sink, right	HS-18F	2.4				
West Gym hallway	Fountain combo, fountain	HS-19A	<1.0				
West Gym hallway	Fountain combo, bottle filler	HS-19B	<1.0				
Training Room off Weightroom	Sink	HS-20	2.3				
Weightroom	Ice machine	HS-21A	<1.0				
Weightroom	Fountain combo, fountain	HS-21B	<1.0				
Weightroom	Fountain combo, bottle filler	HS-21C	<1.0				
West Boy's Locker Room	Fountain combo, fountain	HS-22A	<1.0				
West Boy's locker room	Fountain combo, bottle filler	HS-22B	<1.0				
Short hallway between Quad and Art area	Fountain combo, fountain	HS-23A	<1.0				
Short hallway between Quad and Art area	1 Fountain/Bottle filler	HS-23B	<1.0				
Nurse's office	Sink, left	HS-24A	3.7				
Nurse's office	Sink, right	HS-24B	2.1				
20	Sink	HS-25	2				
21	Sink	HS-26	1.4				
Hallway near 602	Fountain combo, fountain	HS-27A	<1.0				

Hallway near 602	Fountain combo, bottle filler	HS-27B	<1.0				
Hallway near 610	Fountain, regular	HS-28	<1.0				
Hallway near 41	Fountain combo, fountain	HS-30A	<1.0				
Hallway near 41	Fountain combo, bottle filler	HS-30B	<1.0				
District Office, Breakroom	Sink	HS-31	2.3				
2nd floor hallway near 711	Fountain combo, fountain	HS-32A	<1.0				
2nd floor hallway near 711	Fountain combo, bottle filler	HS-32B	<1.0				
2nd floor hallway near 721	Fountain, regular	HS-33	<1.0				
2nd floor Room 709	Sink	HS 34	6.6	faucet and lines, filter	2.9		• 0