

Pine Bush Water Outlets Testing 2024 (no further testing required in 2025)

Room	Outlet	Sample ID	Aug. 2024	Mitigation Description	Nov. 2024
Kitchen	Sink	PBE-1A	1.7		
Kitchen	Sink	PBE-1C	2.6		
Cafeteria	Fountain combo, fountain	PBE-3A	<1.0		
Cafeteria	Fountain combo, bottle filler	PBE-3B	<1.0		
Room 500	Sink	PBE-5	7.8	Replace faucet and shut-offs	3.9
Common Area	Fountain, combo, fountain	PBE-7A	<1.0		
Common Area	Fountain, combo, bottle filler	PBE-7B	<1.0		
100	Sink	PBE-8	<1.0		
101	Sink	PBE-9	<1.0		
102	Sink	PBE-10	3.3		
103	Sink	PBE-11	<1.0		
104	Sink	PBE-12	<1.0		
105	Sink	PBE-13	<1.0		
106	Sink	PBE-14	<1.0		
107	Sink	PBE-15	<1.0		
200	Sink	PBE-16	<1.0		
Hall to Library corner toward 502	Fountain combo, Fountain	N/A	Repaired	Sampled on 2nd round only	<1.0
Hall to Library corner toward 502	Fountain combo, bottle filler	N/A	Repaired	Sampled on 2nd round only	<1.0
502/503	Sink	PBE-18A	<1.0		
502/503	Fountain	PBE-18B	4.7		
Common Area	Fountain combo. Fountain	PBE-20A	<1.0		
Common Area	Fountain/Combo	PBE-20B	<1.0		
201	Sink	PBE -21	7.1	Installed filter	3
202	Sink	PBE-22	<1.0		
203	Sink	PBE-23	<1.0		
204	Sink	PBE-24	<1.0		
205	Sink	PBE-25	<1.0		
206	Sink	PBE-26	<1.0		
207	Sink	PBE-27	<1.0		
208	Sink	PBE-28	<1.0		
Common Area	Fountain, combo, fountain	PBE-29A	<1.0		

Common Area	Fountain combo, bottle filler	PBE-29B	<1.0		
300	Sink	PBE-30	<1.0		
301	Sink	PBE-31	<1.0		
302	Sink	PBE-32	12.6	Replaced faucet and shut-offs	4.6
303	Sink	PBE-33	<1.0		
304	Sink	PBE 34	6.5	Replaced faucet and shut-offs	3.2
305	Sink	PBE-35	<1.0		
604 Copy Room	Sink	PBE-36	24.3	Replaced lines, installed filter	1
605	Sink	PBE-37	<1.0		
Library, room to left of circulation desk	Sink	PBE-38	3.2		
Hall at Library corner toward 605	Fountain combo, fountain	PBE-39A	<1.0		
Hall at Library corner toward 605	Fountain combo, bottle filler	PBE-39B	<1.0		
Common Area	Fountain combo, fountain	PBE-41A	<1.0		
Common Area	Fountain combo, bottle filler	PBE-41B	<1.0		
400	Sink/Fountain (sampled sink)	PBE-42	<1.0	Sampled fountain 2nd round	<1.0
401	Sink	PBE-43	4.9		
402	Sink	PBE-44	<1.0		
403	Sink	PBE-45	<1.0		
404	Sink	PBE-46	<1.0		
405	Sink	PBE-47	<1.0		
406	Sink	PBE-48	<1.0		
Nurse's Office past 603	Sink	PBE-51	1.8		
600 Community Room	Sink	PBE-52	<1.0		