

WES Water Outlets Testing 2024-2025

Room	Outlet	Sample ID	Aug. 2024	Mitigation Description	Nov. 2024	Mitigation Re-Check	Dec. 2025
Conference Room behind Main Office	Sink	WES-1	2.7				
Hallway across from 107	Fountain combo, fountain	WES-2A	<1.0				
Hallway across from 107	Fountain combo, bottle filler	WES-2B	<1.0				
109	Sink on right	WES-3	<1.0				
110	Sink	WES-4A	<1.0				
110	Fountain	WES-4B	<1.0				
111	Sink	WES-5	<1.0				
112	Sink	WES-6	<1.0				
113	Sink	WES-7	<1.0				
114	Sink	WES-8	<1.0				
115	Sink	WES-9	<1.0				
116	Sink	WES-10	<1.0				
117	Sink	WES-11	2.3				
118	Sink	WES-12	1.2				
119	Sink	WES-13	<1.0				
Front Gym, custodian's (Liegeot) office	Sink	WES-14	1.1				
Hallway intersection near Library	Fountain combo, fountain	WES-15A	<1.0				
Hallway interseciton near Library	Fountain combo, bottle filler	WES-15B	<1.0				
122	Sink	WES-16	<1.0				
123	Sink	WES-17	1.4				
124	Sink	WES-18	1.4				
125	Sink	WES-19	4				
126	Sink	WES-20	1				
127	Sink	WES-21	<1.0				
128	Sink	WES-22	1.6				
129	Sink	WES-23	1.6				
130	Sink	WES-24	<1.0				
131	Sink	WES-25	<1.0				
132	Sink	WES-26	1.4				
133	Sink	WES-27	<1.0				
Hallway to left of 207 Nurse's	Fountain combo, fountain	WES-28A	<1.0				
	Fountain combo, bottle filler	WES-28B	<1.0				
Nurse 207	Sink	WES-29	1.1				
Kitchen	Sink	WES-30A	2.1				
Kitchen	Sink	WES-30B	3				
Kitchen	Sink	WES-30C	1				
Kitchen	Sink	WES-30D	2.8				
Kitchen	Sink	WES-30E	1.2				
212	Sink	WES-31	<1.0				
205	Sink	WES 32A	5.1	faucet, lines and shut-offs	<1.0		

205	Fountain	WES 32B	<1.0				
204	Sink	WES-33A	4.1				
204	Fountain	WES-33B	1.9				
203	Sink	WES-34A	1				
203	Fountain	WES-34B	1.4				
202	Sink	WES-35A	<1.0				
202	Fountain	WES-35B	1				
201	Sink	WES-36A	3.2				
149	Sink	WES-37	<1.0				
150	Sink	WES-38	2.3				
147	Sink	WES-39	3.4				
146	Sink	WES-40	3.8				
145	Sink	WES 41	9.2	faucet, lines and shut-offs	10.7	Faucet new, shut-offs not new	8.4
151	Sink	WES-42	3				
152	Sink	WES-43	2				
144	Sink	WES-44	1				
141	Sink	WES-45	<1.0				