



December 20, 2023

William Kotas
Intertek PSI
17 British American Boulevard
Latham, NY 12110

RE: Project: GUILDERLAND CENTRAL SCHOOL
Pace Project No.: 70280703

Dear William Kotas:

Enclosed are the analytical results for sample(s) received by the laboratory on December 13, 2023. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Melville

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

A handwritten signature in cursive script that reads "Lori Beyer".

Lori A. Beyer
lori.beyer@pacelabs.com
516-370-6014
Project Manager

Enclosures



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



CERTIFICATIONS

Project: GUILDERLAND CENTRAL SCHOOL

Pace Project No.: 70280703

Pace Analytical Services Long Island

575 Broad Hollow Rd, Melville, NY 11747

Connecticut Certification #: PH-0435

Delaware Certification # NY 10478

Maryland Certification #: 208

Massachusetts Certification #: M-NY026

New Hampshire Certification #: 2987

New Jersey Certification #: NY158

New York Certification #: 10478 Primary Accrediting Body

Pennsylvania Certification #: 68-00350

Rhode Island Certification #: LAO00340

Virginia Certification # 460302

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE SUMMARY

Project: GUILDERLAND CENTRAL SCHOOL
Pace Project No.: 70280703

Lab ID	Sample ID	Matrix	Date Collected	Date Received
70280703001	GES 14	Drinking Water	12/12/23 06:25	12/13/23 08:15
70280703002	GES 40	Drinking Water	12/12/23 06:23	12/13/23 08:15
70280703003	GES 45	Drinking Water	12/12/23 06:21	12/13/23 08:15
70280703004	GES 57	Drinking Water	12/12/23 06:19	12/13/23 08:15
70280703005	GES 59	Drinking Water	12/12/23 06:20	12/13/23 08:15
70280703006	GES 86	Drinking Water	12/12/23 06:16	12/13/23 08:15
70280703007	GES 97	Drinking Water	12/12/23 06:22	12/13/23 08:15
70280703008	E-169	Drinking Water	12/12/23 07:16	12/13/23 08:15
70280703009	E-170	Drinking Water	12/12/23 07:16	12/13/23 08:15
70280703010	E-170A	Drinking Water	12/12/23 07:15	12/13/23 08:15
70280703011	E-170B	Drinking Water	12/12/23 07:15	12/13/23 08:15
70280703012	W-38	Drinking Water	12/12/23 07:20	12/13/23 08:15
70280703013	LES-15	Drinking Water	12/12/23 06:51	12/13/23 08:15
70280703014	LES-35	Drinking Water	12/12/23 06:54	12/13/23 08:15
70280703015	LES-59	Drinking Water	12/12/23 06:56	12/13/23 08:15
70280703016	LES-74	Drinking Water	12/12/23 06:52	12/13/23 08:15
70280703017	PBE-30	Drinking Water	12/12/23 06:41	12/13/23 08:15
70280703018	PBE-87	Drinking Water	12/12/23 06:38	12/13/23 08:15
70280703019	WES-30	Drinking Water	12/12/23 06:02	12/13/23 08:15
70280703020	WES-97A	Drinking Water	12/12/23 06:04	12/13/23 08:15

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE ANALYTE COUNT

Project: GUILDERLAND CENTRAL SCHOOL

Pace Project No.: 70280703

Lab ID	Sample ID	Method	Analysts	Analytes Reported
70280703001	GES 14	EPA 200.8	JP2	1
70280703002	GES 40	EPA 200.8	JP2	1
70280703003	GES 45	EPA 200.8	JP2	1
70280703004	GES 57	EPA 200.8	JP2	1
70280703005	GES 59	EPA 200.8	JP2	1
70280703006	GES 86	EPA 200.8	JP2	1
70280703007	GES 97	EPA 200.8	JP2	1
70280703008	E-169	EPA 200.8	JP2	1
70280703009	E-170	EPA 200.8	JP2	1
70280703010	E-170A	EPA 200.8	JP2	1
70280703011	E-170B	EPA 200.8	JP2	1
70280703012	W-38	EPA 200.8	JP2	1
70280703013	LES-15	EPA 200.8	JP2	1
70280703014	LES-35	EPA 200.8	JP2	1
70280703015	LES-59	EPA 200.8	JP2	1
70280703016	LES-74	EPA 200.8	JP2	1
70280703017	PBE-30	EPA 200.8	JP2	1
70280703018	PBE-87	EPA 200.8	JJS	1
70280703019	WES-30	EPA 200.8	JP2	1
70280703020	WES-97A	EPA 200.8	JP2	1

PACE-MV = Pace Analytical Services - Melville

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GUILDERLAND CENTRAL SCHOOL

Pace Project No.: 70280703

Sample: GES 14		Lab ID: 70280703001	Collected: 12/12/23 06:25	Received: 12/13/23 08:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	4.3	ug/L	1.0	1		12/18/23 18:56	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GUILDERLAND CENTRAL SCHOOL

Pace Project No.: 70280703

Sample: GES 40		Lab ID: 70280703002	Collected: 12/12/23 06:23	Received: 12/13/23 08:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/18/23 19:00	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GUILDERLAND CENTRAL SCHOOL

Pace Project No.: 70280703

Sample: GES 45		Lab ID: 70280703003	Collected: 12/12/23 06:21	Received: 12/13/23 08:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	3.8	ug/L	1.0	1		12/18/23 19:04	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GUILDERLAND CENTRAL SCHOOL

Pace Project No.: 70280703

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: GES 57								
Lab ID: 70280703004								
Collected: 12/12/23 06:19 Received: 12/13/23 08:15 Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	7.0	ug/L	1.0	1		12/18/23 19:06	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GUILDERLAND CENTRAL SCHOOL

Pace Project No.: 70280703

Sample: GES 59		Lab ID: 70280703005	Collected: 12/12/23 06:20	Received: 12/13/23 08:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/18/23 19:08	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GUILDERLAND CENTRAL SCHOOL

Pace Project No.: 70280703

Sample: GES 86		Lab ID: 70280703006		Collected: 12/12/23 06:16	Received: 12/13/23 08:15	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/18/23 19:09	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GUILDERLAND CENTRAL SCHOOL

Pace Project No.: 70280703

Sample: GES 97		Lab ID: 70280703007		Collected: 12/12/23 06:22	Received: 12/13/23 08:15	Matrix: Drinking Water		
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/18/23 19:11	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GUILDERLAND CENTRAL SCHOOL

Pace Project No.: 70280703

Sample: E-169		Lab ID: 70280703008	Collected: 12/12/23 07:16	Received: 12/13/23 08:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	7.0	ug/L	1.0	1		12/18/23 19:12	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GUILDERLAND CENTRAL SCHOOL

Pace Project No.: 70280703

Sample: E-170		Lab ID: 70280703009	Collected: 12/12/23 07:16	Received: 12/13/23 08:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	10.6	ug/L	1.0	1		12/18/23 19:14	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GUILDERLAND CENTRAL SCHOOL

Pace Project No.: 70280703

Sample: E-170A		Lab ID: 70280703010	Collected: 12/12/23 07:15	Received: 12/13/23 08:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	19.4	ug/L	1.0	1		12/18/23 19:15	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GUILDERLAND CENTRAL SCHOOL

Pace Project No.: 70280703

Sample: E-170B		Lab ID: 70280703011	Collected: 12/12/23 07:15	Received: 12/13/23 08:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	16.6	ug/L	1.0	1		12/18/23 19:17	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GUILDERLAND CENTRAL SCHOOL

Pace Project No.: 70280703

Sample: W-38	Lab ID: 70280703012	Collected: 12/12/23 07:20	Received: 12/13/23 08:15	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	4.5	ug/L	1.0	1		12/18/23 19:18	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GUILDERLAND CENTRAL SCHOOL

Pace Project No.: 70280703

Sample: LES-15		Lab ID: 70280703013	Collected: 12/12/23 06:51	Received: 12/13/23 08:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/18/23 19:23	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GUILDERLAND CENTRAL SCHOOL

Pace Project No.: 70280703

Sample: LES-35		Lab ID: 70280703014	Collected: 12/12/23 06:54	Received: 12/13/23 08:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	4.2	ug/L	1.0	1		12/18/23 19:24	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GUILDERLAND CENTRAL SCHOOL

Pace Project No.: 70280703

Sample: LES-59		Lab ID: 70280703015	Collected: 12/12/23 06:56	Received: 12/13/23 08:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	10.2	ug/L	1.0	1		12/18/23 19:26	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GUILDERLAND CENTRAL SCHOOL

Pace Project No.: 70280703

Sample: LES-74		Lab ID: 70280703016	Collected: 12/12/23 06:52	Received: 12/13/23 08:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		12/18/23 19:27	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GUILDERLAND CENTRAL SCHOOL

Pace Project No.: 70280703

Sample: PBE-30		Lab ID: 70280703017	Collected: 12/12/23 06:41	Received: 12/13/23 08:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	4.0	ug/L	1.0	1		12/18/23 19:29	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GUILDERLAND CENTRAL SCHOOL

Pace Project No.: 70280703

Sample: PBE-87		Lab ID: 70280703018	Collected: 12/12/23 06:38	Received: 12/13/23 08:15	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Preparation Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	58.4	ug/L	1.0	1	12/19/23 09:01	12/19/23 17:10	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GUILDERLAND CENTRAL SCHOOL

Pace Project No.: 70280703

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: WES-30								
Lab ID: 70280703019								
Collected: 12/12/23 06:02								
Received: 12/13/23 08:15								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	2.7	ug/L	1.0	1		12/18/23 19:30	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: GUILDERLAND CENTRAL SCHOOL

Pace Project No.: 70280703

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: WES-97A								
Lab ID: 70280703020								
Collected: 12/12/23 06:04								
Received: 12/13/23 08:15								
Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
Lead	10.5	ug/L	1.0	1		12/18/23 19:32	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: GUILDERLAND CENTRAL SCHOOL

Pace Project No.: 70280703

QC Batch:	331166	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70280703001, 70280703002, 70280703003, 70280703004, 70280703005, 70280703006, 70280703007, 70280703008, 70280703009, 70280703010, 70280703011, 70280703012, 70280703013, 70280703014, 70280703015, 70280703016, 70280703017, 70280703019, 70280703020		

METHOD BLANK:	1696839	Matrix:	Water
Associated Lab Samples:	70280703001, 70280703002, 70280703003, 70280703004, 70280703005, 70280703006, 70280703007, 70280703008, 70280703009, 70280703010, 70280703011, 70280703012, 70280703013, 70280703014, 70280703015, 70280703016, 70280703017, 70280703019, 70280703020		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	12/18/23 18:48	

LABORATORY CONTROL SAMPLE:	1696840					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	50.5	101	85-115	

MATRIX SPIKE SAMPLE:	1696842						
Parameter	Units	70281151002 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	5.7	50	56.5	102	70-130	

MATRIX SPIKE SAMPLE:	1696844						
Parameter	Units	70280703001 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	4.3	50	56.1	104	70-130	

SAMPLE DUPLICATE:	1696841					
Parameter	Units	70281151002 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	5.7	5.9	2	20	

SAMPLE DUPLICATE:	1696843					
Parameter	Units	70280703001 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	4.3	4.3	1	20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: GUILDERLAND CENTRAL SCHOOL

Pace Project No.: 70280703

QC Batch:	331249	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET Drinking Water
		Laboratory:	Pace Analytical Services - Melville

Associated Lab Samples: 70280703018

METHOD BLANK: 1697357 Matrix: Water

Associated Lab Samples: 70280703018

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	12/19/23 17:00	

LABORATORY CONTROL SAMPLE: 1697358

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	50.3	101	85-115	

MATRIX SPIKE SAMPLE: 1697360

Parameter	Units	70280703018 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	58.4	50	102	87	70-130	

SAMPLE DUPLICATE: 1697359

Parameter	Units	70280703018 Result	Dup Result	RPD	Max RPD	Qualifiers
Lead	ug/L	58.4	57.8	1	20	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



QUALIFIERS

Project: GUILDERLAND CENTRAL SCHOOL

Pace Project No.: 70280703

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: GUILDERLAND CENTRAL SCHOOL

Pace Project No.: 70280703

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70280703018	PBE-87	EPA 200.8	331249	EPA 200.8	331273
70280703001	GES 14	EPA 200.8	331166		
70280703002	GES 40	EPA 200.8	331166		
70280703003	GES 45	EPA 200.8	331166		
70280703004	GES 57	EPA 200.8	331166		
70280703005	GES 59	EPA 200.8	331166		
70280703006	GES 86	EPA 200.8	331166		
70280703007	GES 97	EPA 200.8	331166		
70280703008	E-169	EPA 200.8	331166		
70280703009	E-170	EPA 200.8	331166		
70280703010	E-170A	EPA 200.8	331166		
70280703011	E-170B	EPA 200.8	331166		
70280703012	W-38	EPA 200.8	331166		
70280703013	LES-15	EPA 200.8	331166		
70280703014	LES-35	EPA 200.8	331166		
70280703015	LES-59	EPA 200.8	331166		
70280703016	LES-74	EPA 200.8	331166		
70280703017	PBE-30	EPA 200.8	331166		
70280703019	WES-30	EPA 200.8	331166		
70280703020	WES-97A	EPA 200.8	331166		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.

Company Name: Intertek- PSI
 Street Address: 17 British American Blvd, Latham, NY 12110

Customer Project #: 8215303
 Project Name: Guilderland Central School District

Site Collection Info/Facility ID (as applicable):

Time Zone Collected: () AK () PT () MT () CT (X) ET

Data Deliverables:
 () Level II () Level III () Level IV
 () EQUIS
 () Other: _____

Rush (Pre-approval required):
 () 12 Day () 3 day () 15 day () Other _____
 Date Results Requested: Standard 10 business day

Field Filtered (if applicable): () Yes () No

Analysis:
 * Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Waste Water (WW), Product (P), Soil/Solid (SS), Oil (OL), Wipe (WP), Tissue (TS), Bioassay (B), Vapor (V), Other (OT), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk

CHAIN-OF-CUSTODY Analytical Request Document
 Chain-of-Custody is a LEGAL DOCUMENT - Complete all relevant fields

Contact/Report To: Kotas, William
 Phone #: 518-365-1537
 E-Mail: william.kotas@intertek.com
 Cc E-Mail:

Invoice To: Kotas, William
 Invoice E-Mail: william.kotas@intertek.com

Purchase Order # (if applicable):
 Quote #:

County / State origin of sample(s): New York

Regulatory Program (DW, RCRA, etc.) as applicable: NY Lead in School DW

DW PWSID # or WW Permit # as applicable:

Number & Type of Containers: Plastic Glass

Res. CLZ

Composite End Date Time

Collected (or Composite Start) Date Time

Matrix * Comp / Grab

Customer Sample ID

GES 14

GES 40

GES 45

GES 57

GES 59

GES 86

GES 97

E-169

E-170

E-170A

200.8 Drinking Water (Pb only)

X

↓

↓

↓

↓

LAB USE ONLY - Affix Worksheet to this form
WO#: 70280703

 70280703

Specify Container Size **
 **Container Size: (1) 1L (2) 500mL (3) 250mL (4) 125mL (5) 100mL (6) 40mL vial (7) Encare (8) Ferracore (9) Other

Identify Container Preservative Type **
 *** Preservative Types: (1) None, (2) HNO3, (3) H2SO4, (4) HCl, (5) NaOH, (6) Zn Acetate, (7) NaHSO4, (8) Sod. Thiosulfate, (9) Ascorbic Acid, (10) MeOH, (11) Other

Analyst Requested

Proj. Mgr:
 Lori Beyer
 AcctNum / Client ID:

Table #:
 Profile / Template:
 X
 Prelog / Bottle Ord. ID:

Lab Use Only

Sample Comment

Preservation non-conformance identified for

Additional Instructions from Pace*:

Coolers: Thermometer ID: Correction Factor (°C): Obs. Temp. (°C) Corrected Temp. (°C)

Tracking Number:
 Date/Time: 12/12/23 13:30

Delivered by: () In-Person () Courier
 () FedEx () UPS () Other

Date/Time: 12/14/23 02:00
 Date/Time: 12/15/23 8:15

Page: 1 of XZ

ENV-FRM-CORQ-0019_V01_082123 ©

Submitting a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace* Terms and Conditions found at https://www.pacelabs.com/resource-library/resource/pace-terms-and-conditions/

Company Name: Intertek - PSI
 Street Address: 17 British American Blvd, Latham, NY 12110

Customer Project #: 8215303
 Project Name: Guilderland Central School District

Site Collection Info/Facility ID (as applicable):
 Time Zone Collected: () AK () PT () MT () CT (X) ET () AT

Country / State origin of sample(s): New York
 Regulatory Program (DW, RCRA, etc) as applicable: NY Lead in School DW

Rush (Pre-approval required):
 () 12 Day () 3 day () 15 day () Other _____
 Date Results Requested: Standard 10 business day

Field Filtered (if applicable): () Yes () No
 Analyte:

Matrix *
 DW G
 Comp / Grab
 Date Time

Collected (or Composite Start) Date Time
 Res. CL2
 Composite End Date Time
 Number & Type of Containers
 Plastic Glass

Customer Sample ID
 E-170B
 W-38
 LES-15
 LES-35
 LES-59
 PBE-30
 PBE-87
 WES-30
 WES-97A

WO#: 70280703
PM: LAB
Due Date: 12/28/23
CLIENT: INTER-LATHAM

Specify Container Size **
 Identify Container Preservative Type***
 Analysis Requested

**Container Size: (1) 1L, (2) 500mL, (3) 250mL, (4) 125mL, (5) 100mL, (6) 40mL vial, (7) EnCore, (8) TerraCore, (9) Other
 *** Preservative Types: (1) None, (2) HNO3, (3) H2SO4, (4) HCl, (5) NaOH, (6) Zn Acetate, (7) NaHSO4, (8) Sod. Thiosulfate, (9) Ascorbic Acid, (10) MeOH, (11) Other

Proj. Mgr:
 Lorl Beyer
 AcctNum / Client ID:
 Table #:
 Profile / Template:
 Prelog / Bottle Ord. ID:
 Lab Use Only
 Sample Comment

Preservation non-conformance identified for

Additional Instructions from Pace*:
 # Coolers: Thermometer ID: Correction Factor (°C): Obs. Temp. (°C) Corrected Temp. (°C)

Date/Time: 12/12/23 13:30
 Date/Time: 12/12/23 16:00
 Date/Time: 12/12/23 08:00
 Date/Time: 12/12/23 08:15

Tracking Number:
 Delivered by: () In-Person () Courier
 () FedEx () UPS () Other
 Page: 12 of 12

Collected By: WILLIAM A. KOTAS
 Printed Name: WILLIAM A. KOTAS
 Signature: [Signature]

Received by/Company (Signature): [Signature] PACE
 Received by/Company (Signature): [Signature] PACE
 Received by/Company (Signature): [Signature] PACE
 Received by/Company (Signature): [Signature] PACE

Pace* Location Requested (City/State):
 Pace Analytical Long Island NY
 575 Broad Hollow Rd, Melville, NY 11747

Contact/Report To: Kotas, William
 Phone #: 518-365-1537
 E-Mail: william.kotas@intertek.com
 Cc E-Mail:

Invoice To: Kotas, William
 Invoice E-Mail: william.kotas@intertek.com
 Purchase Order # (if applicable):
 Quote #:

Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Surface Water (SW), Sediment (SED), Sludge (SL), Caulk (V), Other (OT)

Customer Remarks / Special Conditions / Possible Hazards:
 Lead

Relinquished by/Company (Signature): [Signature] PSI
 Relinquished by/Company (Signature): [Signature] PACE
 Relinquished by/Company (Signature): [Signature] PACE
 Relinquished by/Company (Signature): [Signature] PACE

Submitting a sample via this chain of custody constitutes acknowledgment and acceptance of the Pace* Terms and Conditions found at <https://www.pacelabs.com/resource-library/resource/pace-terms-and-conditions/>

Client: Inter-Latham

Profile #: 10367

Use Point Number Spreadsheet

Multiday Project

Work ID: GairHaxland Centre/School

COC Page _____ of _____
 Add SCLOGFD to first sample for field charge

Site	Sample ID	Sample Description	Matrix	Container	Volume	Notes
1	BP1U	1L unreserved jar	Water	BP1U	1L unreserved jar	
1	BP2U	2oz unreserved jar	Solid	BP2U	2oz unreserved jar	
1	BP3U	4oz unreserved jar	Non-aqueous liquid	BP3U	4oz unreserved jar	
1	BP4U	16oz unreserved jar	Oil	BP4U	16oz unreserved jar	
1	BP5U	16oz unreserved jar	Wipe	BP5U	16oz unreserved jar	
1	BP6U	16oz unreserved jar	Drinking Water	BP6U	16oz unreserved jar	
1	BP7U	16oz unreserved jar		BP7U	16oz unreserved jar	
1	BP8U	16oz unreserved jar		BP8U	16oz unreserved jar	
1	BP9U	16oz unreserved jar		BP9U	16oz unreserved jar	
1	BP10U	16oz unreserved jar		BP10U	16oz unreserved jar	
1	BP11U	16oz unreserved jar		BP11U	16oz unreserved jar	
1	BP12U	16oz unreserved jar		BP12U	16oz unreserved jar	
1	BP13U	16oz unreserved jar		BP13U	16oz unreserved jar	
1	BP14U	16oz unreserved jar		BP14U	16oz unreserved jar	
1	BP15U	16oz unreserved jar		BP15U	16oz unreserved jar	
1	BP16U	16oz unreserved jar		BP16U	16oz unreserved jar	
1	BP17U	16oz unreserved jar		BP17U	16oz unreserved jar	
1	BP18U	16oz unreserved jar		BP18U	16oz unreserved jar	
1	BP19U	16oz unreserved jar		BP19U	16oz unreserved jar	
1	BP20U	16oz unreserved jar		BP20U	16oz unreserved jar	
1	BP21U	16oz unreserved jar		BP21U	16oz unreserved jar	
1	BP22U	16oz unreserved jar		BP22U	16oz unreserved jar	
1	BP23U	16oz unreserved jar		BP23U	16oz unreserved jar	
1	BP24U	16oz unreserved jar		BP24U	16oz unreserved jar	
1	BP25U	16oz unreserved jar		BP25U	16oz unreserved jar	
1	BP26U	16oz unreserved jar		BP26U	16oz unreserved jar	
1	BP27U	16oz unreserved jar		BP27U	16oz unreserved jar	
1	BP28U	16oz unreserved jar		BP28U	16oz unreserved jar	
1	BP29U	16oz unreserved jar		BP29U	16oz unreserved jar	
1	BP30U	16oz unreserved jar		BP30U	16oz unreserved jar	
1	BP31U	16oz unreserved jar		BP31U	16oz unreserved jar	
1	BP32U	16oz unreserved jar		BP32U	16oz unreserved jar	
1	BP33U	16oz unreserved jar		BP33U	16oz unreserved jar	
1	BP34U	16oz unreserved jar		BP34U	16oz unreserved jar	
1	BP35U	16oz unreserved jar		BP35U	16oz unreserved jar	
1	BP36U	16oz unreserved jar		BP36U	16oz unreserved jar	
1	BP37U	16oz unreserved jar		BP37U	16oz unreserved jar	
1	BP38U	16oz unreserved jar		BP38U	16oz unreserved jar	
1	BP39U	16oz unreserved jar		BP39U	16oz unreserved jar	
1	BP40U	16oz unreserved jar		BP40U	16oz unreserved jar	
1	BP41U	16oz unreserved jar		BP41U	16oz unreserved jar	
1	BP42U	16oz unreserved jar		BP42U	16oz unreserved jar	
1	BP43U	16oz unreserved jar		BP43U	16oz unreserved jar	
1	BP44U	16oz unreserved jar		BP44U	16oz unreserved jar	
1	BP45U	16oz unreserved jar		BP45U	16oz unreserved jar	
1	BP46U	16oz unreserved jar		BP46U	16oz unreserved jar	
1	BP47U	16oz unreserved jar		BP47U	16oz unreserved jar	
1	BP48U	16oz unreserved jar		BP48U	16oz unreserved jar	
1	BP49U	16oz unreserved jar		BP49U	16oz unreserved jar	
1	BP50U	16oz unreserved jar		BP50U	16oz unreserved jar	
1	BP51U	16oz unreserved jar		BP51U	16oz unreserved jar	
1	BP52U	16oz unreserved jar		BP52U	16oz unreserved jar	
1	BP53U	16oz unreserved jar		BP53U	16oz unreserved jar	
1	BP54U	16oz unreserved jar		BP54U	16oz unreserved jar	
1	BP55U	16oz unreserved jar		BP55U	16oz unreserved jar	
1	BP56U	16oz unreserved jar		BP56U	16oz unreserved jar	
1	BP57U	16oz unreserved jar		BP57U	16oz unreserved jar	
1	BP58U	16oz unreserved jar		BP58U	16oz unreserved jar	
1	BP59U	16oz unreserved jar		BP59U	16oz unreserved jar	
1	BP60U	16oz unreserved jar		BP60U	16oz unreserved jar	
1	BP61U	16oz unreserved jar		BP61U	16oz unreserved jar	
1	BP62U	16oz unreserved jar		BP62U	16oz unreserved jar	
1	BP63U	16oz unreserved jar		BP63U	16oz unreserved jar	
1	BP64U	16oz unreserved jar		BP64U	16oz unreserved jar	
1	BP65U	16oz unreserved jar		BP65U	16oz unreserved jar	
1	BP66U	16oz unreserved jar		BP66U	16oz unreserved jar	
1	BP67U	16oz unreserved jar		BP67U	16oz unreserved jar	
1	BP68U	16oz unreserved jar		BP68U	16oz unreserved jar	
1	BP69U	16oz unreserved jar		BP69U	16oz unreserved jar	
1	BP70U	16oz unreserved jar		BP70U	16oz unreserved jar	
1	BP71U	16oz unreserved jar		BP71U	16oz unreserved jar	
1	BP72U	16oz unreserved jar		BP72U	16oz unreserved jar	
1	BP73U	16oz unreserved jar		BP73U	16oz unreserved jar	
1	BP74U	16oz unreserved jar		BP74U	16oz unreserved jar	
1	BP75U	16oz unreserved jar		BP75U	16oz unreserved jar	
1	BP76U	16oz unreserved jar		BP76U	16oz unreserved jar	
1	BP77U	16oz unreserved jar		BP77U	16oz unreserved jar	
1	BP78U	16oz unreserved jar		BP78U	16oz unreserved jar	
1	BP79U	16oz unreserved jar		BP79U	16oz unreserved jar	
1	BP80U	16oz unreserved jar		BP80U	16oz unreserved jar	
1	BP81U	16oz unreserved jar		BP81U	16oz unreserved jar	
1	BP82U	16oz unreserved jar		BP82U	16oz unreserved jar	
1	BP83U	16oz unreserved jar		BP83U	16oz unreserved jar	
1	BP84U	16oz unreserved jar		BP84U	16oz unreserved jar	
1	BP85U	16oz unreserved jar		BP85U	16oz unreserved jar	
1	BP86U	16oz unreserved jar		BP86U	16oz unreserved jar	
1	BP87U	16oz unreserved jar		BP87U	16oz unreserved jar	
1	BP88U	16oz unreserved jar		BP88U	16oz unreserved jar	
1	BP89U	16oz unreserved jar		BP89U	16oz unreserved jar	
1	BP90U	16oz unreserved jar		BP90U	16oz unreserved jar	
1	BP91U	16oz unreserved jar		BP91U	16oz unreserved jar	
1	BP92U	16oz unreserved jar		BP92U	16oz unreserved jar	
1	BP93U	16oz unreserved jar		BP93U	16oz unreserved jar	
1	BP94U	16oz unreserved jar		BP94U	16oz unreserved jar	
1	BP95U	16oz unreserved jar		BP95U	16oz unreserved jar	
1	BP96U	16oz unreserved jar		BP96U	16oz unreserved jar	
1	BP97U	16oz unreserved jar		BP97U	16oz unreserved jar	
1	BP98U	16oz unreserved jar		BP98U	16oz unreserved jar	
1	BP99U	16oz unreserved jar		BP99U	16oz unreserved jar	
1	BP100U	16oz unreserved jar		BP100U	16oz unreserved jar	

Can also be a BPAN

Matrix	Container	Volume
Water	BP1U	1L unreserved plastic
Solid	BP2U	250mL HNO3 plastic
Non-aqueous liquid	BP3U	250mL Sodium Hydroxide
Oil	BP4U	500mL unreserved amber glass
Wipe	BP5U	16oz unreserved jar
Drinking Water	BP6U	16oz unreserved jar

Matrix	Container	Volume
Water	BP1U	1L unreserved plastic
Solid	BP2U	250mL HNO3 plastic
Non-aqueous liquid	BP3U	250mL Sodium Hydroxide
Oil	BP4U	500mL unreserved amber glass
Wipe	BP5U	16oz unreserved jar
Drinking Water	BP6U	16oz unreserved jar

Matrix	Container	Volume
Water	BP1U	1L unreserved plastic
Solid	BP2U	250mL HNO3 plastic
Non-aqueous liquid	BP3U	250mL Sodium Hydroxide
Oil	BP4U	500mL unreserved amber glass
Wipe	BP5U	16oz unreserved jar
Drinking Water	BP6U	16oz unreserved jar

Matrix	Container	Volume
Water	BP1U	1L unreserved plastic
Solid	BP2U	250mL HNO3 plastic
Non-aqueous liquid	BP3U	250mL Sodium Hydroxide
Oil	BP4U	500mL unreserved amber glass
Wipe	BP5U	16oz unreserved jar
Drinking Water	BP6U	16oz unreserved jar

* Can also be a BPAN

Matrix	Container	Volume
Water	BP1U	1L unreserved plastic
Solid	BP2U	250mL HNO3 plastic
Non-aqueous liquid	BP3U	250mL Sodium Hydroxide
Oil	BP4U	500mL unreserved amber glass
Wipe	BP5U	16oz unreserved jar
Drinking Water	BP6U	16oz unreserved jar

Matrix	Container	Volume
Water	BP1U	1L unreserved plastic
Solid	BP2U	250mL HNO3 plastic
Non-aqueous liquid	BP3U	250mL Sodium Hydroxide
Oil	BP4U	500mL unreserved amber glass
Wipe	BP5U	16oz unreserved jar
Drinking Water	BP6U	16oz unreserved jar

Matrix	Container	Volume
Water	BP1U	1L unreserved plastic
Solid	BP2U	250mL HNO3 plastic
Non-aqueous liquid	BP3U	250mL Sodium Hydroxide
Oil	BP4U	500mL unreserved amber glass
Wipe	BP5U	16oz unreserved jar
Drinking Water	BP6U	16oz unreserved jar

Matrix	Container	Volume
Water	BP1U	1L unreserved plastic
Solid	BP2U	250mL HNO3 plastic
Non-aqueous liquid	BP3U	250mL Sodium Hydroxide
Oil	BP4U	500mL unreserved amber glass
Wipe	BP5U	16oz unreserved jar
Drinking Water	BP6U	16oz unreserved jar

Sender Initials _____

Additional Comments: Line 1

WO#: 70280703

Client Name: PSI

Project #

PM: LAB Due Date: 12/28/23
 CLIENT: INTER-LATHAM

Courier: Fed Ex UPS USPS Client Commercial Parcel Other

Tracking #:

Custody Seal on Cooler/Box Present: Yes No Seals intact: Yes No Temperature Blank Present: Yes No
 Packing Material: Bubble Wrap Bubble Bags Ziploc None Other Type of Ice: Wet Blue None

Thermometer Used: TH211 Correction Factor: +0.4 Samples on ice, cooling process has begun
 Cooler Temperature(°C): 11.8 Cooler Temperature Corrected(°C): 12.2 Date/Time 5035A kits placed in freezer _____

Temp should be above freezing to 6.0°C

USDA Regulated Soil (N/A, water sample)

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)? Yes No

Did samples originate from a foreign source including Hawaii and Puerto Rico? Yes No

If Yes to either question, fill out a Regulated Soil Checklist (ENV-FRM-MELV-0076) and include with SCUR/COC paperwork.

Date and Initials of person examining contents: JH 12/13/23

			COMMENTS:
Chain of Custody Present:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	1.
Chain of Custody Filled Out:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	2.
Chain of Custody Relinquished:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	3.
Sampler Name & Signature on COC:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No <input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time:	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	5.
Short Hold Time Analysis (<72hr):	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	6.
Rush Turn Around Time Requested	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No	7.
Sufficient Volume: (Triple volume provided for MS/MSD)	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	8.
Correct Containers Used:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	9.
-Pace Containers Used:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	10.
Containers Intact:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	10.
Filtered volume received for Dissolved tests	<input type="checkbox"/> Yes	<input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	11. Note: if sediment is visible in the dissolved container.
Sample Labels match COC:	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	12.
-Includes date/time/ID/Analysis Matrix:	SL <input checked="" type="checkbox"/> WT OIL OTHER		

Date and Initials of person checking preservation: JH 12/13/23

All containers needing preservation have been	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input checked="" type="checkbox"/> N/A	13. <input type="checkbox"/> HNO ₃ <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> NaOH <input type="checkbox"/> HCl
pH paper Lot # <u>227022V</u>				Sample #
All containers needing preservation are found to be in compliance with method recommendation? (HNO ₃ , H ₂ SO ₄ , HCl, NaOH>9 Sulfide, NAOH>12 Cyanide)	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input type="checkbox"/> N/A	
Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water). Per Method, VOA pH is checked after analysis				Initial when completed: Lot # of added preservative: Date/Time preservative added:
Samples checked for dechlorination:	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input checked="" type="checkbox"/> N/A	14.
KI starch test strips Lot #				Positive for Res. Chlorine? Y N
Residual chlorine strips Lot #				15. Positive for Sulfide? Y N
SM 4500 CN samples checked for sul	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input checked="" type="checkbox"/> N/A	16.
Lead Acetate Strips Lot #				17.
Headspace in VOA Vials (>6mm):	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input checked="" type="checkbox"/> N/A	
Trip Blank Present:	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input checked="" type="checkbox"/> N/A	
Trip Blank Custody Seals Present	<input type="checkbox"/> Yes	<input type="checkbox"/> No	<input checked="" type="checkbox"/> N/A	

DATE AND INITIALS OF PERSON COMPLETING SECOND REVIEW: MPL 12/14

Client Notification/ Resolution:

Field Data Required? Y / N

Person Contacted:

Date/Time:

Comments/ Resolution:

* PM (Project Manager) review is documented electronically in LIMS.