Experience is the solution
314 North Pearl Street ♦ Albany, New York 12207
(800) 848-4983 ♦ (518) 434-4546 ♦ Fax (518) 434-0891

November 10, 2026

Clifford Nooney
Guilderland CSD
PO Box 381
Guilderland Center, NY 12085
TEL: (518) 456-6200

Work Order No: 261001008

RE:
High School

Adirondack Environmental Services, Inc received 7 samples on 10/1/2026 for the analyses presented in the following report.

Please see case narrative for specifics on analysis.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,

ELAP#: 10709

Christopher Hess
QA Manager

Adirondack Environmental Services, Inc — CASE NARRATIVE

Guilderland CSD

Date: *10-Nov-26*

High School

Lab WorkOrder: **261001008**

The sampling was performed in accordance with the AES field sampling procedures and/or the client specified sampling procedures. Sample containers were supplied by Adirondack Environmental Services.

This is an updated report to include just Lead. (Rev01)

Definitions - RL: Reporting Limit DF: Dilution factor

Qualifiers:

ND : Not Detected at reporting limit	C: CCV below acceptable Limits
J: Analyte detected below quantitation limit	C+: CCV above acceptable Limits
B: Analyte detected in Blank	S: LCS Spike recovery is below acceptable limits
X : Exceeds maximum contamination limit	S+: LCS Spike recovery is above acceptable limits
H: Hold time exceeded	Z: Duplication outside acceptable limits
N: Matrix Spike below acceptable limits	T : Tentatively Identified Compound-Estimated
N+: Matrix Spike is above acceptable limits	E :Above quantitation range-Estimated

Note : All Results are reported as wet weight unless noted

The results relate only to the items tested. Information supplied by the client is assumed to be correct.

Adirondack Environmental Services, Inc

Date: *10-Nov-26*

CLIENT:	Guilderland CSD	**Client Sample ID:**	E-169
Work Order:	**261001008**	**Collection Date:**	10/1/2026 6:15:00 AM
Reference:	/ High School	**Lab Sample ID:**	261001008-001
PO#:		**Matrix:**	DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4						Analyst: **KH**
(Prep: - 10/1/2026 1:00:05 PM)						
Lead	**13.2**	1.0	X	µg/L	1	10/7/2026 2:53:39 PM

Adirondack Environmental Services, Inc

Date: *10-Nov-26*

CLIENT:	Guilderland CSD	**Client Sample ID:**	E-170
Work Order:	**261001008**	**Collection Date:**	10/1/2026 6:15:00 AM
Reference:	/ High School	**Lab Sample ID:**	261001008-002
PO#:		**Matrix:**	DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4						Analyst: **KH**
(Prep: - 10/1/2026 1:00:05 PM)						
Lead	**6.7**	1.0	X	µg/L	1	10/7/2026 3:04:23 PM

Adirondack Environmental Services, Inc

Date: *10-Nov-26*

CLIENT:	Guilderland CSD	**Client Sample ID:**	E-170A
Work Order:	**261001008**	**Collection Date:**	10/1/2026 6:16:00 AM
Reference:	/ High School	**Lab Sample ID:**	261001008-003
PO#:		**Matrix:**	DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4						Analyst: **KH**
(Prep: - 10/1/2026 1:00:05 PM)						
Lead	**10.9**	1.0	X	µg/L	1	10/7/2026 3:15:07 PM

Adirondack Environmental Services, Inc

Date: *10-Nov-26*

CLIENT:	Guilderland CSD	**Client Sample ID:**	E-170B
Work Order:	**261001008**	**Collection Date:**	10/1/2026 6:16:00 AM
Reference:	/ High School	**Lab Sample ID:**	261001008-004
PO#:		**Matrix:**	DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4						Analyst: **KH**
(Prep: - 10/1/2026 1:00:05 PM)						
Lead	**5.5**	1.0	X	µg/L	1	10/7/2026 3:18:42 PM

Adirondack Environmental Services, Inc

Date: *10-Nov-26*

CLIENT:	Guilderland CSD	**Client Sample ID:**	W-33
Work Order:	**261001008**	**Collection Date:**	10/1/2026 6:08:00 AM
Reference:	/ High School	**Lab Sample ID:**	261001008-005
PO#:		**Matrix:**	DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4						Analyst: **KH**
(Prep: - 10/1/2026 1:00:05 PM)						
Lead	**2.1**	1.0		µg/L	1	10/7/2026 3:22:18 PM

Adirondack Environmental Services, Inc

Date: *10-Nov-26*

CLIENT:	Guilderland CSD	**Client Sample ID:**	W-38
Work Order:	**261001008**	**Collection Date:**	10/1/2026 6:07:00 AM
Reference:	/ High School	**Lab Sample ID:**	261001008-006
PO#:		**Matrix:**	DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
ICP/MS - EPA 200.8 REV 5.4						Analyst: **KH**
(Prep: - 10/1/2026 1:00:05 PM)						
Lead	**15.6**	1.0	X	µg/L	1	10/7/2026 3:25:54 PM

Adirondack Environmental Services, Inc

Date: *10-Nov-26*

CLIENT:	Guilderland CSD	**Client Sample ID:**	W-47
Work Order:	**261001008**	**Collection Date:**	10/1/2026 6:09:00 AM
Reference:	/ High School	**Lab Sample ID:**	261001008-007
PO#:		**Matrix:**	DRINKING WATER

Analyses	Result	RL	Qual	Units	DF	Date Analyzed
FIELD-PH, RES CL2, AND TEMP ARE NOT ELAP CERTIFIABLE						Analyst: **FLD**
Observation	**No Flow**			NA		10/1/2026 6:09:00 AM

Adirondack Environmental Services Inc.
314 North Pearl Street
Albany, New York 12207
518-434-4546 ♦ Fax: 518-434-0891

CHAIN OF CUSTODY RECORD

AES Work Order#: 261001008 MG

EXPERIENCE IS THE SOLUTION

A full service analytical research laboratory offering solutions to environmental concerns

Client Name: Guilderland CSD	**Address**	
Send Report to:	**Project Name (Location):** High School	**Samplers Name:** Derek Merker
Client Email:	**PO #:**	**Samplers Signature:**
Client Fax No:		

AES Sample ID	Client Sample ID:	Date Sampled	Time A=am P=pm		Sample Type Matrix	C	G	# of Cont's	Analysis
001	E-169	10/1/26	06:15	A P	PW		G	1	Pb, Cu
002	E-170	10/1/26	06:15	A P	PW		G	1	Pb, Cu
003	E-170A	10/1/26	06:16	A P	PW		G	1	Pb, Cu
004	E-170B	10/1/26	06:16	A P	PW		G	1	Pb, Cu
005	W-33	10/1/26	06:08	A P	PW		G	1	Pb, Cu
006	W-38	10/1/26	06:07	A P	PW		G	1	Pb, Cu
007	W-47	10/1/26	06:09	A P	PW		G	10	~~Pb, Cu~~ No flow
				A P					
				A P					
				A P					
				A P					
				A P					

Shipment Arrived Via:
FedEx UPS Client (AES)
Other:

Special Instructions/Remarks:

Turnaround Time Requested:

Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received by: (Signature) MG	Date 10/1/26	Time 8:27

Sample Temperature
Ambient Chilled
Chilling Process begun

Notes: _____

Properly Preserved
(Y) N

Notes: _____

Received Within Holding Times
(Y) N

Notes: _____

261001008

Adirondack Environmental Services Inc.®
Experience is the solution
314 North Pearl Street • Albany, New York 12207 • (518) 434-4546 • Fax (518) 434-0891

TERMS, CONDITIONS & LIMITATIONS

All service rendered by the **Adirondack Environmental Services, Inc.** are undertaken and all rates are based upon the following terms:

(a) Neither **Adirondack Environmental Services, Inc.,** nor any of its employees, agents or sub-contractors shall be liable for any loss or damage arising out of **Adirondack Environmental Services, Inc.'s** performance or nonperformance, whether by way of negligence or breach of contract, or otherwise, in any amount greater than twice the amount billed to the customer for the work leading to the claim of the customer. Said remedy shall be the sole and exclusive remedy against **Adirondack Environmental Services, Inc.** arising out of its work.

(b) All claims made must be in writing within forty-five (45) days after delivery of the **Adirondack Environmental Services, Inc.** report regarding said work or such claim shall be deemed or irrevocably waived.

(c) **Adirondack Environmental Services, Inc.** reports are submitted in writing and are for our customers only. Our customers are considered to be only those entities being billed for our services. Acquisition of an **Adirondack Environmental Services, Inc.** report by other than our customer does not constitute a representation of **Adirondack Environmental Services, Inc.** as to the accuracy of the contents thereof.

(d) In no event shall **Adirondack Environmental Services, Inc.,** its employees, agents or sub-contractors be responsible for consequential or special damages of any kind or in any amount.

(e) No deviation from the terms set forth herein shall bind **Adirondack Environmental Services, Inc.** unless in writing and signed by a Director of **Adirondack Environmental Services, Inc.**

(f) Results pertain only to items analyzed. Information supplied by client is assumed to be correct. This information may be used on reports and in calculations and **Adirondack Environmental Services, Inc.** is not responsible for the accuracy of this information.

(g) Payments by Credit Card/Purchase Cards are subject to a 3% additional charge.